




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**RIG 879**  
Machine Id  
**R879-HPU**  
Component  
**Hydraulic System**  
Fluid

**AW HYDRAULIC OIL ISO 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KL0013935</b>	KL0013174	KL0013137
Sample Date	Client Info	<b>11 Feb 2024</b>	01 Dec 2023	09 Nov 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	<b>0</b>	0	0
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >75	<b>1</b>	1	0
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 5	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 5	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m 25	<b>6</b>	3	3
Calcium	ppm	ASTM D5185m 200	<b>57</b>	50	60
Phosphorus	ppm	ASTM D5185m 300	<b>340</b>	326	337
Zinc	ppm	ASTM D5185m 370	<b>433</b>	415	430
Sulfur	ppm	ASTM D5185m 2500	<b>2330</b>	2210	2236

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >20	<b>3</b>	2	2
Sodium	ppm	ASTM D5185m	<b>2</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>1</b>	0	0
Water	%	ASTM D6304 >0.1	<b>NEG</b>	NEG	NEG

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 18152</b>	461	1779
Particles >6µm	ASTM D7647 >1300	<b>▲ 1390</b>	134	543
Particles >14µm	ASTM D7647 >160	<b>36</b>	9	42
Particles >21µm	ASTM D7647 >40	<b>7</b>	2	13
Particles >38µm	ASTM D7647 >10	<b>0</b>	0	1
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 21/18/12</b>	16/14/10	18/16/13

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.57	<b>0.31</b>	0.22	0.30




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.26	48.9
Visc @ 100°C	cSt	ASTM D445	6.7	7.2	---
Viscosity Index (VI)	Scale	ASTM D2270	97	115	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0013935 **Received** : 22 Feb 2024  
**Lab Number** : 06097333 **Tested** : 26 Feb 2024  
**Unique Number** : 10890186 **Diagnosed** : 26 Feb 2024 - Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, VI )  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**PATTERSON - UTI DRILLING**  
 9915 WEST INDUSTRIAL  
 MIDLAND, TX  
 US 79706  
 Contact: RICKY MATA  
 ricky.mata@patenergy.com  
 T: (832)219-4559  
 F: (432)561-9388