




OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area

Preparation-Prep CBL MILL

Machine Id

[Preparation-Prep CBL MILL] 360006002 - CBL MILL BULL GEAR RIGHT

Component

Right Gearbox

Fluid

SHELL OMALA S2 G 680 (18 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TLC0001383	TLC0001383	TLC0001089
Sample Date	Client Info	01 Feb 2024	01 Feb 2024	19 Oct 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	12	142	123	
Iron	ppm	ASTM D5185m >200	45	121	142
Chromium	ppm	ASTM D5185m >15	2	0	<1
Nickel	ppm	ASTM D5185m >15	<1	0	<1
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	<1	2
Lead	ppm	ASTM D5185m >100	0	<1	0
Copper	ppm	ASTM D5185m >200	3	0	<1
Tin	ppm	ASTM D5185m >25	<1	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	1	0	0
Barium	ppm	ASTM D5185m	0	0	19
Molybdenum	ppm	ASTM D5185m	0	0	<1
Manganese	ppm	ASTM D5185m	<1	2	<1
Magnesium	ppm	ASTM D5185m	7	0	1
Calcium	ppm	ASTM D5185m	403	124	135
Phosphorus	ppm	ASTM D5185m	271	185	270
Zinc	ppm	ASTM D5185m	54	0	13
Sulfur	ppm	ASTM D5185m	7313	9735	10397

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	5	<1	4
Sodium	ppm	ASTM D5185m	16	11	12
Potassium	ppm	ASTM D5185m >20	1	2	3
Water	%	ASTM D6304 >0.2	NEG	NEG	NEG

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 149887	---	---
Particles >6µm	ASTM D7647 >5000	▲ 43163	---	---
Particles >14µm	ASTM D7647 >640	55	---	---
Particles >21µm	ASTM D7647 >160	3	---	---
Particles >38µm	ASTM D7647 >40	0	---	---
Particles >71µm	ASTM D7647 >10	0	---	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 24/23/13	---	---


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.13	0.51	0.50




OIL ANALYSIS REPORT


Particle Trend




Viscosity @ 100°C




PQ



Viscosity @ 40°C



Acid Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	680	▲ 58.01	698
Visc @ 100°C	cSt	ASTM D445	38	▲ 8.61	---
Viscosity Index (VI)	Scale	ASTM D2270	92	122	---

SAMPLE IMAGES

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : TLC0001383
 Lab Number : 06097336
 Unique Number : 10890189
 Test Package : PLANT (Additional Tests: KF, KV100, PrtCount, VI)

Received : 22 Feb 2024
 Tested : 27 Feb 2024
 Diagnosed : 27 Feb 2024 - Jonathan Hester

MICHELIN US 10
 16 BIBB WAY
 ANDERSON, SC
 US 29626

Contact: TERRICK PRESLEY
 terrick.presley@michelin.com

T: (803)761-8053

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)