




FUEL REPORT

Sample Rating Trend



NORMAL



Machine Id
IDEM FODT 6

Component
Diesel Fuel
Fluid

DIESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation

ASTM D240 result 18,900 BTU/lb. Test performed at subcontracted ISO 17025 laboratory. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0911757	WC0901677	WC0892751
Sample Date	Client Info			15 Feb 2024	14 Jan 2024	15 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Sample Status				NORMAL	NORMAL	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.862	0.863	0.862
Fuel Color	text	*Visual Screen		Red	Red	Red
ASTM Color	scalar	*ASTM D1500		L4.5	L5.5	L5.0
Visc @ 40°C	cSt	ASTM D445	4.1	2.64	2.62	2.7
Pensky-Martens Flash Point	°C	*PMCC Calculated		60	59	59
Cloud Point	°C	ASTM D5771		-23	-23	-23
Pour Point	°C	ASTM D5950		-36	-35	-37

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		6	4	14
Sulfur (UVF)	ppm	ASTM D5453		14	13	14

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		166	166	165
5% Distillation Point	°C	ASTM D86		193	193	192
10% Distill Point	°C	ASTM D86		205	205	206
15% Distillation Point	°C	ASTM D86		216	216	216
20% Distill Point	°C	ASTM D86		224	224	225
30% Distill Point	°C	ASTM D86		239	240	239
40% Distill Point	°C	ASTM D86		252	253	252
50% Distill Point	°C	ASTM D86		264	265	264
60% Distill Point	°C	ASTM D86		277	276	276
70% Distill Point	°C	ASTM D86		289	289	289
80% Distill Point	°C	ASTM D86		302	303	303
85% Distillation Point	°C	ASTM D86		311	311	311
90% Distill Point	°C	ASTM D86		321	321	321
95% Distillation Point	°C	ASTM D86		337	337	338
Final Boiling Point	°C	ASTM D86		348	348	349
Distillation Residue	%	ASTM D86		1.4	1.4	1.4
Distillation Loss	%	ASTM D86		0.6	0.8	0.6


IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		32.7	32.5	32.7
Cetane Index		ASTM D4737	<40.0	41.0	41.0	41.1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	0
Sodium	ppm	ASTM D5185m	<0.1	<1	<1	<1
Potassium	ppm	ASTM D5185m	<0.1	<1	<1	0
Water	%	ASTM D6304	<0.05	0.003	0.008	0.004
ppm Water	ppm	ASTM D6304	<500	29	83	46
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0




FUEL REPORT


Fuel Distillation Curve




Particle Count




Water (KF)



Viscosity @ 40°C




Particle Trend



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	336	831	942
Particles >6µm	ASTM D7647	>640	110	257	350
Particles >14µm	ASTM D7647	>80	13	39	35
Particles >21µm	ASTM D7647	>20	4	15	10
Particles >38µm	ASTM D7647	>4	0	1	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	16/14/11	17/15/12	17/16/12

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	0
Nickel	ppm	ASTM D5185m <0.1	0	<1	0
Lead	ppm	ASTM D5185m <0.1	0	0	0
Vanadium	ppm	ASTM D5185m <0.1	0	0	0
Iron	ppm	ASTM D5185m <0.1	0	0	0
Calcium	ppm	ASTM D5185m <0.1	<1	1	0
Magnesium	ppm	ASTM D5185m <0.1	0	1	0
Phosphorus	ppm	ASTM D5185m <0.1	0	0	0
Zinc	ppm	ASTM D5185m <0.1	0	0	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0911757 **Received** : 22 Feb 2024
Lab Number : **06097352** **Tested** : 12 Mar 2024
Unique Number : 10890205 **Diagnosed** : 12 Mar 2024 - Doug Bogart
Test Package : DF-3 (Additional Tests: Screen)

PETROLEUM TECHNOLOGIES GROUP
 4665 BROADMOOR AVE, SUITE 150
 GRAND RAPIDS, MI
 US 49512
 Contact: JAMES KRAFT
 james@oil-lab.com
 T: (616)698-9399
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)