


OIL ANALYSIS REPORT







Machine Id **HYD WEST 2-8**

Component Hydraulic System

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.


Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PH0003266		
Sample Date		Client Info		13 Feb 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	VI	method	limit/base	current	history1	history2
	V					Historyz
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0		
Chromium	ppm	ASTM D5185m	>20	<1		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	0		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	<1		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		33		
Phosphorus	ppm	ASTM D5185m		320		
Zinc	ppm	ASTM D5185m		325		
Sulfur	ppm	ASTM D5185m		3352		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	326		
Particles >6µm		ASTM D7647	>2500	87		
Particles >14µm		ASTM D7647	>320	9		
Particles >21µm		ASTM D7647	>80	3		
Particles >38µm		ASTM D7647	>20	0		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	16/14/10		
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
					,	,




Acid Number (AN) mg KOH/g ASTM D8045

Report Id: NIPLAN [WUSCAR] 06097655 (Generated: 06/24/2024 12:13:21) Rev: 1

Contact/Location: MIKE GUTYAN - NIPLAN



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06097655 Unique Number : 10890508

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PH0003266

Tested Diagnosed

Received

: 22 Feb 2024

: 26 Feb 2024

: 26 Feb 2024 - Jonathan Hester

Test Package: PLANT (Additional Tests: PrtFilter) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NPAA - NIPPON PAINT AUTOMOTIVE AMERICAS

2701 E 170TH ST LANSING, IL US 60438

Contact: MIKE GUTYAN wcgfldemo@gmail.com

T: F: