

### **OIL ANALYSIS REPORT**

#### Sample Rating Trend

ISO

# **T188140 (S/N 1214)**

#### Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of particulates present in the oil.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Dec2022	Feb2024		
SAMPLE INFORM	<b>NATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011595	KCP52428	
Sample Date		Client Info		12 Feb 2024	22 Dec 2022	
Machine Age	hrs	Client Info		6248	4639	
Oil Age	hrs	Client Info		0	2600	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ATTENTION	ABNORMAL	
			11.0011/10.000			history.0
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	1	7	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	13	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	70	35	
Calcium	ppm	ASTM D5185m		4	0	
Phosphorus	ppm	ASTM D5185m	0	5	0	
Zinc		ASTM D5185m		8	0	
Sulfur	ppm			-	19669	
	ppm	ASTM D5185m	23500	18029		
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm		>25	7	<1	
Sodium	ppm	ASTM D5185m		18	10	
Potassium	ppm	ASTM D5185m	>20	2	3	
Water	%	ASTM D6304	>0.05	0.017	0.017	
ppm Water	ppm	ASTM D6304	>500	171	179.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5128	33215	
Particles >6µm		ASTM D7647	>1300	<b>1</b> 359	<b>20064</b>	
Particles >14µm		ASTM D7647	>80	57	<b>9</b> 47	
Particles >21µm		ASTM D7647	>20	15	<u> </u>	
Particles >38μm		ASTM D7647	>4	1	4	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/13</b>	A 22/22/17	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.37	0.30	
	ing K∪⊓/g	70 HVI D0040	1.0	0.37	0.50	



## **OIL ANALYSIS REPORT**





Certificate L2367

-₹3 45 Bas

40

35

回留

Abnormal

Se

Contact/Location: MIKE PAPOLA - MIKSANCA