


OIL ANALYSIS REPORT



^{Machine Id} 6962075 (S/N 1084) Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate concentration of water present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011941	KCPA007683	KCP37485
Sample Date		Client Info		15 Feb 2024	14 Nov 2023	15 Apr 2021
Machine Age	hrs	Client Info		20841	19244	6434
Oil Age	hrs	Client Info		0	0	6434
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	4
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	<1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		2	2	3
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m		2	10	14
Tin	ppm	ASTM D5185m	>10	2 <1	<1	<1
Antimony		ASTM D5185m	>10			0
Vanadium	ppm	ASTM D5185m		0	0	0
	ppm			0		
Cadmium	ppm	ASTM D5185m		U	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	11
Barium	ppm	ASTM D5185m	90	4	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	41	<1	0
Calcium	ppm	ASTM D5185m	0	5	<1	0
Phosphorus	ppm	ASTM D5185m	0	3	0	7
Zinc	ppm	ASTM D5185m	0	28	2	22
Sulfur	ppm	ASTM D5185m	23500	18562	20309	18470
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	<u> </u>	6
Sodium	ppm	ASTM D5185m		3	0	0
Potassium	ppm	ASTM D5185m	>20	2	1	<1
Water	%	ASTM D6304	>0.05	<u> </u>	0.005	▲ 0.253
ppm Water	ppm	ASTM D6304	>500	6010	50	<u> </u>
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			29123	
Particles >6µm		ASTM D7647	>1300		8873	
Particles >14µm		ASTM D7647	>80		▲ 556	
Particles >21µm		ASTM D7647	>20		A 84	
Particles >38µm		ASTM D7647	>4		1	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		▲ 22/20/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.47	0.56	0.429
·22·45) Bov: 1	ing ivor ing	. 10 1 10 00040			PHIL CERVAN	


Report Id: PACTRA [WUSCAR] 06097696 (Generated: 02/25/2024 14:22:45) Rev: 1


Contact/Location: PHIL CERVANTES - PACTRA



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	🔺 MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	A 0.2%	NEG	▲ 0.2%
Free Water	scalar	*Visual		▲ >10%	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	47.5	49.8	46.7
SAMPLE IMAGES method		method	limit/base	current	history1	history2
Color					•	

Bottom



Й7

Contact/Location: PHIL CERVANTES - PACTRA