

OIL ANALYSIS REPORT

PT Ì

Sample Rating Trend

WEAR

Machine Id

KAESER DSD 150 9003513 (S/N 1240)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2023	Feb 2024			
SAMPLE INFORMA	MOIT	method	limit/base	current	h	istory1	history2
	TION		IIIIIIIIIIIIII				HISTOTYZ
Sample Number		Client Info		KC123216	KC12		
Sample Date		Client Info		05 Feb 2024	15 No	v 2023	
Machine Age	nrs	Client Info		2378	1995		
0	nrs	Client Info		0	0		
Oil Changed		Client Info		N/A	N/A		
Sample Status				ABNORMAL	ABNC	RMAL	
WEAR METALS		method	limit/base	current	h	istory1	history2
Iron p	opm	ASTM D5185m	>50	0	0		
Chromium p	opm	ASTM D5185m	>10	0	0		
Nickel	opm	ASTM D5185m	>3	0	0		
Titanium	opm	ASTM D5185m	>3	0	0		
Silver p	opm	ASTM D5185m	>2	0	0		
Aluminum p	opm	ASTM D5185m	>10	1 4	1 4		
Lead r	opm	ASTM D5185m	>10	0	0		
	opm	ASTM D5185m	>50	<1	0		
	opm	ASTM D5185m	>10	<1	0		
	opm	ASTM D5185m		0	0		
	opm	ASTM D5185m		0	0		
ADDITIVES		method	limit/base	current	h	istory1	history2
Boron r	opm	ASTM D5185m		0	0		
	opm	ASTM D5185m	90	0	0		
	opm	ASTM D5185m		0	0		
	opm	ASTM D5185m		<1	0		
	opm	ASTM D5185m	90	<1	0		
	opm	ASTM D5185m	2	1	0		
	opm	ASTM D5185m	_	59	60		
	opm	ASTM D5185m		0	0		
CONTAMINANTS		method	limit/base	current	h	istory1	history2
	opm		>25	2	2		
	opm	ASTM D5185m	720	- <1	0		
	opm	ASTM D5105m	>20	2	1		
'	%	ASTM D6304		0.002	0.0	02	
	opm	ASTM D6304		17	18	02	
FLUID CLEANLINE	SS	method	limit/base	current	h	istory1	history2
Particles >4μm		ASTM D7647		45465	692		
Particles >6µm		ASTM D7647	>1300	<u> </u>	2 04	19	
Particles >14µm		ASTM D7647	>80	▲ 800	▲ 14 ⁻		
Particles >21µm		ASTM D7647	>20	<u> </u>	3 3		
Particles >38µm		ASTM D7647	>4	<u> </u>	1		
Particles >71µm		ASTM D7647		0	0		
ου ου συ		100 4400 ()	(4=:::0	A 00/0::-=	A 00	40/44	

ISO 4406 (c) >--/17/13 **A 23/21/17**

limit/base

current

0.21

method

mg KOH/g ASTM D8045 0.4

Oil Cleanliness

Acid Number (AN)

FLUID DEGRADATION

▲ 20/18/14

0.14

history1

history2



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number

: KC123216 : 06097707

Unique Number: 10890560 Test Package : IND 2

Received **Tested**

Diagnosed

: 23 Feb 2024 : 25 Feb 2024 - Don Baldridge

4620 WEST 84TH ST INDIANAPOLIS, IN US 46268

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: