




OIL ANALYSIS REPORT

Sample Rating Trend

VIS DEBRIS

Area
FOUR MILE RIDGE [20005315]
 Machine Id
83440 SITE 15
 Component
Wind Turbine Gearbox
 Fluid
CASTROL OPTIGEAR SYNTHETIC X 320 (--- LTR)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		NX012359	NX004210	NX010430
Sample Date	Client Info		05 Oct 2023	03 Apr 2023	08 Dec 2022
Machine Age	hrs	Client Info	68284	62805	62643
Oil Age	hrs	Client Info	68284	62805	62643
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184	>80	13	14	7
Iron	ppm	ASTM D5185m	>150	4	1
Chromium	ppm	ASTM D5185m	>5	0	0
Nickel	ppm	ASTM D5185m	>10	0	0
Titanium	ppm	ASTM D5185m	>10	0	0
Silver	ppm	ASTM D5185m		0	0
Aluminum	ppm	ASTM D5185m	>10	7	<1
Lead	ppm	ASTM D5185m	>20	0	0
Copper	ppm	ASTM D5185m	>50	1	<1
Tin	ppm	ASTM D5185m	>10	<1	0
Vanadium	ppm	ASTM D5185m		<1	0
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		36	0
Barium	ppm	ASTM D5185m		3	0
Molybdenum	ppm	ASTM D5185m	1150	918	649
Manganese	ppm	ASTM D5185m		<1	<1
Magnesium	ppm	ASTM D5185m		10	9
Calcium	ppm	ASTM D5185m	2000	1768	1234
Phosphorus	ppm	ASTM D5185m	400	367	321
Zinc	ppm	ASTM D5185m	0	0	0
Sulfur	ppm	ASTM D5185m	1850	2048	1532

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	11	8
Sodium	ppm	ASTM D5185m	>20	1	5
Potassium	ppm	ASTM D5185m	>20	<1	0
Water	%	ASTM D6304	>0.05	0.023	0.017
ppm Water	ppm	ASTM D6304	>500	231	174.5

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		---	4778	50068
Particles >6µm	ASTM D7647	>2500	---	849	▲ 15783
Particles >14µm	ASTM D7647	>320	---	57	▲ 683
Particles >21µm	ASTM D7647	>80	---	14	▲ 95
Particles >38µm	ASTM D7647	>20	---	1	6
Particles >71µm	ASTM D7647	>4	---	0	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	---	19/17/13	▲ 23/21/17

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.6	1.19	0.67




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	330	318	316

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : NX012359

Lab Number : 06097723

Unique Number : 10890576

Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

Received : 22 Feb 2024

Tested : 25 Feb 2024

Diagnosed : 25 Feb 2024 - Doug Bogart

NORDEX USA - Chicago

300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL

US 60606

Contact: DEVIN LINEHAN

DLinehan@nordex-online.com

T: (312)386-4124

F: (312)386-7102

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)