


OIL ANALYSIS REPORT

AIRLUBE 268 [1402465] ATLAS COPCO 11AH-BLO-502B - NRG SEWARD (S/N AIF117071)

Component

Compressor



Sample Rating Trend



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		UCH06097820	UCH06052039	UCH05901351	
Sample Date		Client Info		13 Feb 2024	30 Nov 2023	23 Jun 2023	
Machine Age	hrs	Client Info		99270	97580	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	Changed	N/A	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATION		method	limit/base	current	history1	history2	
Water		WC Method	>0.1	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	0	
Chromium	ppm	ASTM D5185m	>5	<1	0	0	
Nickel	ppm	ASTM D5185m		<1	0	0	
Titanium	ppm	ASTM D5185m		<1	0	0	
Silver	ppm	ASTM D5185m		<1	0	0	
Aluminum	ppm	ASTM D5185m	>15	<1	0	1	
Lead	ppm	ASTM D5185m	>65	<1	0	0	
Copper	ppm	ASTM D5185m	>65	<1	<1	0	
Tin	ppm	ASTM D5185m	>10	<1	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	0	
Cadmium	ppm	ASTM D5185m		<1	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0.6	0	0	0	
Barium	ppm	ASTM D5185m	0.1	5	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	0	
Manganese	ppm	ASTM D5185m	0.4	<1	0	0	
Magnesium	ppm	ASTM D5185m	0	0	0	<1	
Calcium	ppm	ASTM D5185m	0	0	0	0	
Phosphorus	ppm	ASTM D5185m	337	189	256	271	
Zinc	ppm	ASTM D5185m	0.1	2	0	0	
Sulfur	ppm	ASTM D5185m	1096	1111	1120	1337	
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>35	<1	0	0	
Sodium	ppm	ASTM D5185m		0	0	0	
Potassium	ppm	ASTM D5185m	>20	<1	0	<1	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.414	0.138	0.08	0.05	



OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2


1 LOID I HOI LITTI						
Visc @ 40°C	cSt	ASTM D445	67.21	65.7	64.7	64.6


SAMPLE IMAGES


Color


Bottom















Certificate L2367

Laboratory Sample No. Lab Number : 06097820 Unique Number: 10896050

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06097820

Received

Tested Diagnosed

: 23 Feb 2024 : 25 Feb 2024 - Don Baldridge

: 22 Feb 2024

AIR TECHNOLOGIES INC (PIT) 310 PLUM INDUSTRIAL CT

PITTSBURGH, PA US 15239

Contact: MIKE STRAZZERA

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. mike.strazzera@aircompressors.com T: (724)327-2818

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (412)788-4799 Contact/Location: MIKE STRAZZERA - UCAIRPIT