

OIL ANALYSIS REPORT

Area ULTRA COOLANT [SVO-58688] Machine Id INGERSOLL RAND VK3017U15010 - LKQ

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






NORMAL

		اء و والد و وا			la i a ta mut	biotow 0
SAMPLE INFORM	ATION	method	limit/base		history1	history2
Sample Number		Client Info		UCH06097847		
Sample Date		Client Info		30 Jan 2024		
Machine Age	hrs	Client Info		15275		
Oil Age	hrs	Client Info		3515		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	1		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1		
Barium	ppm	ASTM D5185m	500	408		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	0	<1		
Calcium	ppm	ASTM D5185m	0	2		
Phosphorus	ppm	ASTM D5185m	20	0		
Zinc	ppm	ASTM D5185m	0	5		
Sulfur	ppm	ASTM D5185m	200	248		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		64		
Potassium	ppm	ASTM D5185m	>20	17		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.05		



OIL ANALYSIS REPORT

VISUAL



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Jan30/24	Appearance	scalar	*Visual	NORML	NORML		
Jano	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
1	Free Water	scalar	*Visual		NEG		
	FLUID PROPER	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	49.4	52.5		
	SAMPLE IMAGE	<i>د</i>	method	limit/base	current	history1	history2
		0	method	iiiiii/base	current	Thistory I	mistoryz
Jan30/24	Color				•	no image	no image
	Bottom					no image	no image
	Ferrous Alloys			Jan30/24			
	Viscosity @ 40°C			(0)AL02 (0)AL0	Acid Number		
notes test methods that	: WearCheck USA - 50 : UCH06097847 : 06097847 : 10896077	Rece Teste Diagr vice at 1-8	ived : 22 ed : 23 nosed : 25 800-237-1369 ope of accred	r, NC 27513 2 Feb 2024 3 Feb 2024 Feb 2024 - Dor 9. <i>litation.</i>	JOHN n Baldridge Col	ntact: RACHEL rvonh T:	ER COMPAN RGET STREE NT LOUIS, M US 6313

Contact/Location: RACHEL VON HATTEN - UCJOHSAI