

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area ULTRA COOLANT Machine Id INGERSOLL RAND VFF1739U17317 - MONNIG IND Component

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


				Feb2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH0000465		
Sample Date		Client Info		05 Feb 2024		
Machine Age	hrs	Client Info		25359		
Oil Age	hrs	Client Info		2921		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	J	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	1		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	500	755		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	0	<1		
Calcium	ppm	ASTM D5185m	0	2		
Phosphorus	ppm	ASTM D5185m	20	0		
Zinc	ppm	ASTM D5185m	0	72		
Sulfur	ppm	ASTM D5185m	200	254		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		17		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.664		



OIL ANALYSIS REPORT

VISUAL





					,	,
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	IES	method	limit/base	curren	t history1	history2
Visc @ 40°C	cSt	ASTM D445	49.4	52.4		
SAMPLE IMAGES			limit/bass		t bioton/1	history
SAMPLE IMAGES	Þ	method	limit/base	curren	t history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS						
Ferrous Alloys						
8 iron 6 iron 4 iron 2 iron 4 iron 1 irokel 4 iron 1 irokel 4 iron 1 irokel 4 iron 1 irokel 1			Feb5/24			
Non-ferrous Metal			Feb5/24			
Viscosity @ 40°C				Acid Num	her	
⁷⁰ Severe			₆ 2.	ro		
Abnormal			-2- -2- -1 I -1 -1 -1 -2 -2 -2 -2 -2 -2 -2 -2 -2 -2 -2 -2 -2	00-		
60 Automai 55 - 50 - Absemal			ຍັ 1.	50 Abnormal		
			-e1. 2	50		
45 Severe				00		
Feb5/24			Feb5/24 -	Feb 5/24 -		Feb 5/24 -
WearCheck USA - 50 UCH0000465 06097876 10896106 IND 2 ontact Customer Servi	Receiv Testeo Diagn	ved : 22 d : 23 osed : 25	, NC 27513 2 Feb 2024 3 Feb 2024 Feb 2024 - Do	J	SAI	RGET STREET NT LOUIS, MO US 63134
	7025 000		y. litatian			(214)E02 1267

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

C+ IAN°CI

:

Laboratory

Sample No.

Lab Number Unique Number Test Package

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Ø

Contact/Location: RACHEL VON HATTEN - UCJOHSAI

T: (314)593-1267

F: (314)874-0965