

### **OIL ANALYSIS REPORT**

Sample Rating Trend

**NORMAL** 

# Machine Id KAESER SK 20T 8473056 (S/N 1462)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Feb 2024		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC123218		
Sample Date		Client Info		05 Feb 2024		
Machine Age	hrs	Client Info		2930		
Oil Age	hrs	Client Info		0		
Oil Changed	1110	Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
	10.10.100	ASTM D5185m	>50		history1	
Iron	ppm			<1 <1		
Chromium	ppm	ASTM D5185m	>10			
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m		<1		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m		3		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	24		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	71		
Calcium	ppm	ASTM D5185m	2	2		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		8		
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		22		
Potassium	ppm	ASTM D5185m	>20	8		
Water	%	ASTM D6304	>0.05	0.015		
ppm Water	ppm	ASTM D6304	>500	154		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3171		
Particles >6μm		ASTM D7647	>1300	968		
Particles >14μm		ASTM D7647	>80	62		
Particles >21µm		ASTM D7647	>20	11		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.33



## **OIL ANALYSIS REPORT**



Certificate L2367

Unique Number : 10896635

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2

: 28 Feb 2024 - Jonathan Hester

Diagnosed

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 47460

T:

F:

Contact: SERVICE MANAGER