




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
VP-26
 Component
Pump
 Fluid
USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | USPM30119 | USPM31232 | USPM27093 |
| Sample Date | Client Info | | 22 Feb 2024 | 07 Nov 2023 | 17 Jul 2023 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | NORMAL | NORMAL | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >90 | <1 | 0 | 1 |
| Chromium | ppm | ASTM D5185m >5 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >5 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m >3 | <1 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >7 | <1 | <1 | 2 |
| Lead | ppm | ASTM D5185m >12 | <1 | 0 | <1 |
| Copper | ppm | ASTM D5185m >30 | <1 | 0 | <1 |
| Tin | ppm | ASTM D5185m >9 | <1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | <1 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m 0 | <1 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | <1 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Calcium | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m 1800 | 864 | 904 | 1200 |
| Zinc | ppm | ASTM D5185m 0 | 2 | <1 | <1 |
| Sulfur | ppm | ASTM D5185m 0 | 0 | 0 | 43 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >60 | 3 | <1 | 2 |
| Sodium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Potassium | ppm | ASTM D5185m >20 | <1 | 0 | <1 |
| Water | % | ASTM D6304 >.1 | 0.048 | 0.015 | 0.086 |
| ppm Water | ppm | ASTM D6304 >1000 | 487 | 157.3 | 869.1 |

FLUID CLEANLINESS






| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-----------------|----------|------------|
| Particles >4µm | ASTM D7647 | >5000 | 632 | 323 | ▲ 10200 |
| Particles >6µm | ASTM D7647 | >1300 | 178 | 97 | ▲ 2849 |
| Particles >14µm | ASTM D7647 | >160 | 18 | 14 | ▲ 222 |
| Particles >21µm | ASTM D7647 | >40 | 6 | 7 | ▲ 65 |
| Particles >38µm | ASTM D7647 | >10 | 1 | 3 | 3 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 1 | 1 |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14 | 16/15/11 | 16/14/11 | ▲ 21/19/15 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|-----------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.05 | 0.094 | 0.056 | 0.167 |




OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >.1 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 91 | 99.5 | 98.6 | 90.7 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USPM30119
 Lab Number : 06098458
 Unique Number : 10896688
 Test Package : IND 2
 Received : 23 Feb 2024
 Tested : 26 Feb 2024
 Diagnosed : 26 Feb 2024 - Doug Bogart

JBS FOODS
 BROOKS, AB
 CA T1R 1C6
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: