

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area AIRLUBE 228 [1407099] Machine Id ATLAS COPCO AIA1845686 - BARNES RESEARCH Component

Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Feb2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06098520		
Sample Date		Client Info		12 Feb 2024		
Machine Age	hrs	Client Info		75330		
Oil Age	hrs	Client Info		6281		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	<1		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	<1		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1.5	0		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m	0.3	<1		
Magnesium	ppm	ASTM D5185m	0	<1		
Calcium	ppm	ASTM D5185m	0	<1		
Phosphorus	ppm	ASTM D5185m	406	78		
Zinc	ppm	ASTM D5185m	0	12		
Sulfur	ppm	ASTM D5185m	1283	0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.463	0.57		



0.60

(B/HO)

₽°0.36

g 0.2

P 0.12

0.00

54

52

> 44 Abno 42 4(

Ũ

Feb12/24

leb1

Abnormal

OIL ANALYSIS REPORT

Acid Number NONE *Visual NONE White Metal scalar Yellow Metal *Visual NONE NONE scalar Precipitate scalar *Visual NONE NONE Silt scalar *Visual NONE NONE Debris NONE *Visual NONE scalar Sand/Dirt NONE NONE scalar *Visual Feb12/24 -NORML Appearance scalar *Visual NORML Odor *Visual NORML NORML scalar **Emulsified Water** scalar *Visual >0.1 NEG Viscosity @ 40°C Free Water scalar *Visual NEG FLUID PROPERTIES Visc @ 40°C cSt ASTM D445 47.9 51.1 SAMPLE IMAGES Feb12/24 Color no image no image Bottom no image no imade GRAPHS Ferrous Alloys -ha -9 Non-ferrous Metals Feb12/24 Viscosity @ 40°C Acid Number (B^{0.60} 55 Ab 공 0.48 () 50 (10°C) Ē 0.36 Ba ेतु रहे 45 -e 0.24 0.12 View 0.00 Abnorm 40 Feb12/24. Feb12/24 2/24 Feb 1 -8 **AIR TECHNOLOGIES INC (MID)** Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : UCH06098520 400 WRIGHT AVE Received : 23 Feb 2024 Lab Number : 06098520 MIDDLETOWN, OH Tested : 26 Feb 2024 Unique Number : 10896750 : 26 Feb 2024 - Don Baldridge US 45044 Diagnosed Test Package : IND 2 Contact: KEITH HAYES Certificate L2367 Keith.Hayes@aircompressors.com To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (513)615-6378

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: KEITH HAYES - UCAIRMID

F: (513)539-6040