


OIL ANALYSIS REPORT



AIRLUBE 228 [1402755] ATLAS COPCO AIF083-950 - MIDDLETOWN TUBEWORKS Component

Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		UCH06098532	UCH05984896	UCH05984895	
Sample Date		Client Info	nfo 02 Jan		02 Oct 2023	30 Aug 2023	
Machine Age	hrs	Client Info	70572 69662		69662	69415	
Oil Age	hrs	Client Info	2002		1092	845	
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATION	٧	method	limit/base	current	history1	history2	
Water		WC Method	>0.1	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	0	
Nickel	ppm	ASTM D5185m		<1	0	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m		0	0	0	
Aluminum	ppm	ASTM D5185m	>25	2	<1	<1	
Lead	ppm	ASTM D5185m	>25	0	0	0	
Copper	ppm	ASTM D5185m	>50	0	1	1	
Tin	ppm	ASTM D5185m	>15	<1	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	1.5	0	0	0	
Barium	ppm	ASTM D5185m	0	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	0	
Manganese	ppm	ASTM D5185m	0.3	<1	<1	<1	
Magnesium	ppm	ASTM D5185m	0	<1	0	0	
Calcium	ppm	ASTM D5185m	0	<1	2	2	
Phosphorus	ppm	ASTM D5185m	406	178	175	185	
Zinc	ppm	ASTM D5185m	0	8	0	0	
Sulfur	ppm	ASTM D5185m	1283	536	989	1004	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	0	0	0	
Sodium	ppm	ASTM D5185m		<1	2	2	
Potassium	ppm	ASTM D5185m	>20	<1	0	0	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.463	0.26	0.093	0.092	



OIL ANALYSIS REPORT



Jan2/24


VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIFS	method	limit/base	current	history1	history2


I LOID I NOI LINILO		memou			HISTOLAL	HISTOLYZ	
Visc @ 40°C	cSt	ASTM D445	47.9	45.8	44.8	44.9	


SAMPLE IMAGES


Color


Bottom















Certificate L2367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06098532 Lab Number : 06098532

Unique Number : 10896762 Test Package : IND 2

Received : 23 Feb 2024 **Tested** : 26 Feb 2024 Diagnosed

: 26 Feb 2024 - Don Baldridge

400 WRIGHT AVE MIDDLETOWN, OH US 45044

AIR TECHNOLOGIES INC (MID)

Contact: Josh Oaks josh.oaks@aircompressors.com

F: (513)539-6040

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCAIRMID [WUSCAR] 06098532 (Generated: 02/26/2024 15:04:37) Rev: 1

Contact/Location: Josh Oaks - UCAIRMID

T: