

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Plant US1 Greenville Machine Id BD-7 - Roller Nose Gearbox

Gearbox Fluid

MOBIL SHC 634 (12 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Feb2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TLC0001550		
Sample Date		Client Info		19 Feb 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		17		
Iron	ppm	ASTM D5185m	>200	0		
Chromium	ppm	ASTM D5185m	>15	0		
Nickel	ppm	ASTM D5185m	>15	<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>100	0		
Copper	ppm	ASTM D5185m	>200	<1		
Tin	ppm	ASTM D5185m	>25	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		1		
Calcium	ppm	ASTM D5185m		1		
Phosphorus	ppm	ASTM D5185m		865		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		226		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	13		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.53		



OIL ANALYSIS REPORT

0.48 - 0.36 - 1.24 -		White Metal	scalar					
0.24			Scalai	*Visual	NONE	NONE		
0.24		Yellow Metal	scalar	*Visual	NONE	NONE		
).24		Precipitate	scalar	*Visual	NONE	NONE		
		Silt	scalar	*Visual	NONE	NONE		
D.12		Debris	scalar	*Visual	NONE	NONE		
		Sand/Dirt	scalar	*Visual	NONE	NONE		
100.00 L	1/24	Appearance	scalar	*Visual	NORML	NORML		
Feb 19/24	Feb19/24	Odor	scalar	*Visual	NORML	NORML		
		Emulsified Water	scalar	*Visual	>0.2	NEG		
Viscosity @ 40°C		Free Water	scalar	*Visual	> 0.L	NEG		
500 - Abnormal		FLUID PROPER		method	limit/base		history1	history2
480		Visc @ 40°C	cSt	ASTM D445		current 456		
460								
420 - Abnormal		SAMPLE IMAGE	8	method	limit/base	current	history1	history2
192 1930 1937 1938 1938 1939 1939 1939 1939 1939 1939	Feb19/24 -	Color				a	no image	no image
PQ 200 Severe		Bottom					no image	no image
150 Abnormal		GRAPHS						
		Ferrous Alloys				PQ		
50-		¹⁰			220	Τ.		
0		8 - iron			200	Severe		
Feb 19/24	A CL D F	E 6 - nickel			180			
-e-	Lab	° 4-						
		2			160			
		24 L 0			+Z 140			
		Feb 19/24			Feb19/24			
					관 문 100	Abnormal		
		Non-ferrous Meta	ls					
		copper			80			
		- 6+			60			
					40			
		2			20			
		0						
		Feb19/24			Feb19/24	9/24		V C
		Feb			Feb	Feb 19/24		E-4.19.74
		Viscosity @ 40°C				Acid Number		
		550			0.60			
	_	500 Abnormal			(B/H0.48			
	(40°C	450 - Base			Ĕ 0.36			
	SS	400 - Abnormal	*******		90.24 Pipe 0.24 Pipe 0.12	-		
					[≥] 0.12			
		350 4						24
		Feb 19/24			Feb19/24	Feb 19/24		Eek19.74
Certificate L2867 Te To discuss this sa	ample No. : ab Number : nique Number : est Package : umple report, c	10896801	Recei Teste Diagr	ved : 20 d : 20 losed : 20	3 Feb 2024 5 Feb 2024 3 Feb 2024 - W 9.	140 'es Davis		HURCH ROAL Greenville, SO US 2960 icolas Jackson