




# OIL ANALYSIS REPORT

Sample Rating Trend



## VISCOSITY



Area  
**Fresh gallon blow mold room**  
 Machine Id  
**755-FG-BMM-01-E (S/N N0100AA030135)**  
 Component  
**Top Gear Extruder**  
 Fluid  
**GEAR OIL ISO 220 (--- GAL)**

### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The oil viscosity is lower than normal. Confirmed. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USP0007676</b>	USP234965	USP228852
Sample Date	Client Info		<b>14 Feb 2024</b>	19 Jun 2023	06 Sep 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >150	<b>51</b>	14	10
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>1</b>	0	0
Lead	ppm	ASTM D5185m >100	<b>&lt;1</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>1</b>	<1	10
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 50	<b>21</b>	20	0
Barium	ppm	ASTM D5185m 15	<b>0</b>	2	0
Molybdenum	ppm	ASTM D5185m 15	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m 50	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m 50	<b>6</b>	16	29
Phosphorus	ppm	ASTM D5185m 350	<b>240</b>	270	299
Zinc	ppm	ASTM D5185m 100	<b>18</b>	28	210
Sulfur	ppm	ASTM D5185m 12500	<b>5851</b>	6661	5641

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>15</b>	20	1
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	3	0
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	0
Water	%	ASTM D6304 >0.1	<b>0.002</b>	0.009	0.008
ppm Water	ppm	ASTM D6304 >1000	<b>18</b>	96.0	83.5

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>▲ 176767</b>	▲ 138173	▲ 83452
Particles >6µm	ASTM D7647	>5000	<b>▲ 115442</b>	▲ 32148	4133
Particles >14µm	ASTM D7647	>640	<b>▲ 4968</b>	181	22
Particles >21µm	ASTM D7647	>160	<b>▲ 176</b>	15	3
Particles >38µm	ASTM D7647	>40	<b>1</b>	0	1
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 25/24/19</b>	▲ 24/22/15	▲ 24/19/12


### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	<b>0.60</b>	0.98	0.33




# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Viscosity @ 40°C



## Acid Number




## Water (KF)



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	LIGHT	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220 ▲ 151.6	209	190

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : USP0007676  
 Lab Number : 06099171  
 Unique Number : 10897401  
 Test Package : IND 2

Received : 23 Feb 2024  
 Tested : 27 Feb 2024  
 Diagnosed : 27 Feb 2024 - Doug Bogart

**KROGER MOUNTAIN VIEW FOODS**  
 10241 EAST 51ST AVE  
 DENVER, CO  
 US 80239  
 Contact: CHARLES AMMERMAN

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: