


# OIL ANALYSIS REPORT

Sample Rating Trend



VIS DEBRIS



Area  
**Paper Cup Machines**  
 Machine Id  
**PMC 1003 POS-214 (S/N 15960)**  
 Component  
**Circulating System**  
 Fluid  
**SUMMIT Syngear SH-1032 320 (85 GAL)**

**DIAGNOSIS**

**Recommendation**

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

**Wear**

All component wear rates are normal.

**Contamination**

High concentration of visible dirt/debris present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO50002209</b>	TO50001517	TO50001955
Sample Date	Client Info	<b>21 Feb 2024</b>	14 Feb 2024	12 Jan 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>Not Chngd</b>	Filtered	Filtered
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

**WEAR METALS**

method	limit/base	current	history1	history2	
PQ	ASTM D8184	<b>12</b>	17	13	
Iron	ppm	ASTM D5185m	<1	2	0
Chromium	ppm	ASTM D5185m	0	0	0
Nickel	ppm	ASTM D5185m	2	2	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m	0	0	0
Lead	ppm	ASTM D5185m	0	0	0
Copper	ppm	ASTM D5185m	<1	<1	2
Tin	ppm	ASTM D5185m	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

**ADDITIVES**

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	4	8	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	0	0	<1
Magnesium	ppm	ASTM D5185m	0	0	<1
Calcium	ppm	ASTM D5185m	0	0	1
Phosphorus	ppm	ASTM D5185m	171	203	150
Zinc	ppm	ASTM D5185m	0	0	0
Sulfur	ppm	ASTM D5185m	1500	1918	1464

**CONTAMINANTS**

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	828	990	1291
Sodium	ppm	ASTM D5185m	<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	0
Water	%	ASTM D6304	0.042	0.013	0.012
ppm Water	ppm	ASTM D6304	420	137	123






**FLUID CLEANLINESS**

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>1300	---	---	▲ 22097
Particles >6µm	ASTM D7647	>320	---	---	▲ 1372
Particles >14µm	ASTM D7647	>80	---	---	18
Particles >21µm	ASTM D7647	>20	---	---	4
Particles >38µm	ASTM D7647	>4	---	---	1
Particles >71µm	ASTM D7647	>3	---	---	0
Oil Cleanliness	ISO 4406 (c)	>17/15/13	---	---	▲ 22/18/11

**FLUID DEGRADATION**

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.42	0.45	0.37


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	▲ HEAVY	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	0.2%	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	326	330	334
Visc @ 100°C	cSt	ASTM D445	33.4	35.3	35.1
Viscosity Index (VI)	Scale	ASTM D2270	145	152	149

**SAMPLE IMAGES**



**GRAPHS**



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO50002209 **Received** : 26 Feb 2024  
**Lab Number** : 06100119 **Tested** : 28 Feb 2024  
**Unique Number** : 10898349 **Diagnosed** : 28 Feb 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PQ, PrtCount, VI )

**DART CONTAINER CORPORATION**  
 4444 W LEADBETTER DR  
 DALLAS, TX  
 US 75236  
 Contact: YON PALOMINO  
 yon.palomino@dart.biz  
 T: (214)775-5673  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)