


# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**KAESER 5392584**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA010985</b>	KCPA0039851	KCP47201D
Sample Date	Client Info	<b>18 Dec 2023</b>	06 Jun 2023	28 Oct 2022
Machine Age	hrs	<b>19680</b>	18720	17586
Oil Age	hrs	<b>0</b>	0	2500
Oil Changed	Client Info	<b>N/A</b>	N/A	Changed
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1	0
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>14</b>	8	21
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 90	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	0
Magnesium	ppm	ASTM D5185m 100	<b>2</b>	28	2
Calcium	ppm	ASTM D5185m 0	<b>0</b>	0	2
Phosphorus	ppm	ASTM D5185m 0	<b>0</b>	5	5
Zinc	ppm	ASTM D5185m 0	<b>95</b>	59	29
Sulfur	ppm	ASTM D5185m 23500	<b>16093</b>	22817	19550

### CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Sodium	ppm	ASTM D5185m	<b>4</b>	8	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	1	<1
Water	%	ASTM D6304 >0.05	<b>0.007</b>	0.018	0.005
ppm Water	ppm	ASTM D6304 >500	<b>70</b>	189.3	57.4






### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>19267</b>	---	11825
Particles >6µm	ASTM D7647 >1300	▲ <b>10903</b>	---	▲ 2833
Particles >14µm	ASTM D7647 >80	▲ <b>2550</b>	---	▲ 140
Particles >21µm	ASTM D7647 >20	▲ <b>853</b>	---	▲ 36
Particles >38µm	ASTM D7647 >4	▲ <b>49</b>	---	2
Particles >71µm	ASTM D7647 >3	<b>2</b>	---	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ <b>21/21/19</b>	---	▲ 21/19/14

### FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.38</b>	0.39	0.41

# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	<b>LIGHT</b>	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	<b>46.7</b>	46.2	46.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA010985 **Received** : 26 Feb 2024  
**Lab Number** : 06100160 **Tested** : 27 Feb 2024  
**Unique Number** : 10898390 **Diagnosed** : 28 Feb 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**AMERICAN DISPOSAL SERVICES INC**  
 25 NORTH DR  
 ACWORTH, GA  
 US 30102  
 Contact: W GUERARA  
 WGUERARA@ADSIMAIL.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)