


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**WATER** 

# KAESER SX 5 6222783 (S/N 1025)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### **DIAGNOSIS**

### Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

### Contamination

There is a light concentration of water present in the oil. Excessive free water present.

### **Fluid Condition**

The AN level is acceptable for this fluid.

		Oct2015	Dec2020	Dec2022 Fe	52024	
SAMPLE INFORMA	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011577	KCP48158D	KCP27420
Sample Date		Client Info		12 Feb 2024	07 Dec 2022	04 Dec 2020
Machine Age	hrs	Client Info		5932	3963	1961
Oil Age	hrs	Client Info		0	1997	1178
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
	ppm	ASTM D5185m	>10	0	4	4
	ppm	ASTM D5185m	>50	5	13	2
	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
	ppm	ASTM D5185m		0	0	0
	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
	ppm	ASTM D5185m	90	<1	<1	33
	ppm	ASTM D5185m	0	0	0	<1
	ppm	ASTM D5185m		<1	<1	<1
	ppm	ASTM D5185m	100	15	8	30
	ppm	ASTM D5185m	0	0	2	7
	ppm	ASTM D5185m	0	0	16	18
	ppm	ASTM D5185m	0	60	79	55
	ppm	ASTM D5185m	23500	16485	22611	17649
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	3	2
	ppm	ASTM D5185m		17	14	41
	ppm	ASTM D5185m	>20	<1	2	0
	%	ASTM D6304	>0.05	<b>0.160</b>	<b>△</b> 0.195	0.009
	ppm	ASTM D6304	>500	<b>1600</b>	<u> </u>	96.6
FLUID CLEANLINE	SS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			1244	6854
Particles >6µm		ASTM D7647	>1300		678	2220
Particles >14µm		ASTM D7647	>80		<u> </u>	132
Particles >21µm		ASTM D7647	>20		39	_ 25
Particles >38µm		ASTM D7647	>4		6	2
Particles >71µm		ASTM D7647	>3		1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		17/17/14	18/14
FLUID DEGRADAT	ION	method	limit/base	current	history1	history2

mg KOH/g ASTM D8045 1.0

Acid Number (AN)


0.27


0.15


0.214




## **OIL ANALYSIS REPORT**












	G	RA	۱PI	HS
--	---	----	-----	----


Color

**Bottom** 











Report Id: SYMWIL [WUSCAR] 06100161 (Generated: 02/28/2024 20:22:07) Rev: 1

Laboratory Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Unique Number** : 10898391

: KCPA011577 : 06100161

Received **Tested** 

Diagnosed

: 26 Feb 2024 : 28 Feb 2024

: 28 Feb 2024 - Don Baldridge

WILMINGTON, MA

US 01887 Contact:

SYMBOTIC LLC

200 RESEARCH DR

T: F:

Test Package: IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ? ? - SYMWIL