

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area PNEUTECH PG 46 Machine Id PNEUTECH AK100019818 - IP-44644 Component

Compressor

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


				Feb2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000507		
Sample Date		Client Info		01 Feb 2024		
Machine Age	hrs	Client Info		5295		
Oil Age	hrs	Client Info		4000		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	J	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium		ASTM D5185m		0		
Nickel	ppm	ASTM D5185m	210	0		
Titanium	ppm ppm	ASTM D5185m		0		
Silver		ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	- 25	0		
Lead	ppm	ASTM D5185m	>25	۰ <1		
Copper	ppm ppm	ASTM D5185m		<1		
Tin		ASTM D5185m	>15	<1		
Vanadium	ppm ppm	ASTM D5185m	>15	0		
Cadmium	ppm	ASTM D5185m		0		
	ррпп			Ū		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		473		
Zinc	ppm	ASTM D5185m		18		
Sulfur	ppm	ASTM D5185m		108		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.07		






OIL ANALYSIS REPORT

VISUAL





	VICONE		method	in in base	Current	Thistory	motoryz	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Feb1/24 -	Appearance	scalar	*Visual	NORML	NORML			
Feb	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
				Pres 1 /le s s s				
	FLUID PROPERT		method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		45.9			
1	SAMPLE IMAGES	6	method	limit/base	current	history1	history2	
Feb1/24 +	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Metal	s		Feb1/24				
	ead H			Feb 1/24				
	Viscosity @ 40°C				Acid Number			
	50 Abnormal			0.0 0.0 (M(0) 0.0 (Mg 0.0 (Mg 0.0 (Mg 0.0 (Mg))				
	40 Abnormal			0.0 Nur	2 -			
	35				54 54			
	Feb1/24			Feb1/24	Feb1/24			
Laboratory	: WearCheck USA - 50 ⁻	1 Madisor	Madison Ave., Cary, NC 27513 Received : 26 Feb 2024 Tested : 27 Feb 2024 Diagnosed : 28 Feb 2024 - Jonathan Hester e at 1-800-237-1369. e			FLUID-AIRE DYNAMIC 550 ALBION AV SCHAUMBURG, US 6019 Contact: ED DIENE d.diener@fluidairedynamics.co		

Report Id: UCFLUSCH [WUSCAR] 06100243 (Generated: 02/28/2024 12:00:55) Rev: 1

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ED DIENER - UCFLUSCH

F: