

# **OIL ANALYSIS REPORT**

Sample Rating Trend



#### Area WQ Machine Id DODGE 00101 Component Gearbox

#### Fluid GEAR OIL ISO 220 (1 GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.


## Fluid Condition

The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0721336	WC0570399	WC0524330
Sample Date		Client Info		25 Feb 2024	17 Jan 2023	07 Feb 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	NORMAL	ATTENTION
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	62	102	81
Chromium	ppm	ASTM D5185m	>15	0	0	<1
Nickel	ppm	ASTM D5185m	>15	<1	0	<1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	5	6	6
Lead	ppm	ASTM D5185m	>100	<1	0	0
Copper	ppm	ASTM D5185m	>200	<1	0	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Antimony	ppm	ASTM D5185m	>5			0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	12	8	5
Barium	ppm	ASTM D5185m	15	0	0	0
Molybdenum	ppm	ASTM D5185m	15	<1	1	<1
Manganese	ppm	ASTM D5185m		<1	1	<1
Magnesium	ppm	ASTM D5185m	50	3	2	2
Calcium	ppm	ASTM D5185m	50	12	8	8
Phosphorus	ppm	ASTM D5185m	350	202	171	178
Zinc	ppm	ASTM D5185m	100	0	3	2
Sulfur	ppm	ASTM D5185m	12500	10285	14106	14366
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	21	33	23
Sodium	ppm	ASTM D5185m		2	0	1
Potassium	ppm	ASTM D5185m	>20	4	3	2
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	0.51	0.44	0.45



# **OIL ANALYSIS REPORT**



ficate L2367 discuss this	Laboratory Sample No. Lab Number Unique Number Test Package s sample report,	: 10898488	Recei Teste Diagr	ived : 26 ed : 0 <sup>-</sup> nosed : 01	6 Feb 2024 I Mar 2024 Mar 2024 - Jona	S.M. LORUSSO & SON 221 NORFOLK ST WALPOLE, M unan Hester US 0208 Contact: PAUL BECKMAN pbeckman@smlorusso.cor T: (508)668-260			
		25 150	Feb7/22	Jan 17/23	Feb.25/24	Abnormal Abnormal Bers 1/18	Feb7/22 +	Jan 17/23	Eab 2C/24
		250 Base 200 Bibliotimal 3 150			ي ي ي ي ي ي	Abnormal	· · · · · · · · · · · · · · · · · · ·	I	
		Viscosity @ 40°C		ت				7	ŭ
		Nov1/17 Dec31/18	Feb7/22	Jan 17/23	Feb25/24	Nov1/17 Dec31/18	Feb7/22	Jan17/23	Eah 75/74
		0				0 Abnormal			_
		400 Severe Abnormal				50 Severe			
		Copper (ppm)		-ń		Silicon (ppm)		->	ŭ
		Nov1/17	Feb7/22 -	Jan 17/23 -	Feb25/24 -	Nov1/17	Feb7/22 .	Jan 17/23 ·	Eah 75/74
		abnormal			E dd	20 Abnormal			
		100 Severe				<sup>60</sup> Severe			
		Aluminum (ppm)	)			Chromium (pp	om)	~	
		Nov1/17 Dec31/18	Feb7/22	Jan 17/23	Feb25/24	Nov1/17 Dec31/18	Feb7/22	Jan 17/23	Lotor
		0	22	3		0	2	23	
		400 200 200			트 <sup>20</sup>				
		Iron (ppm)				Lead (ppm)			
		GRAPHS							
		Bottom				no image	no image	no image	,
Feb7/22	Jan 17/23	Color				no image	no image	no image	è
		SAMPLE IMAGE	ES	method	limit/base	current	history1	history	′2
		Visc @ 40°C	cSt	ASTM D445	220	<mark> </mark> 160.9	202	136.7	
		FLUID PROPER	TIES	method	limit/base	current	history1	history	<i>י</i> 2
		Free Water	scalar	*Visual	-	NEG	NEG	NEG	
	-; Ľ	Odor Emulsified Water	scalar scalar	*Visual *Visual	NORML >0.2	NORML NEG	NORML NEG	NORML NEG	
Feb7/22	Jan 17/23 Feb 25/24	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML	
¥		Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE	
		Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT	
/	$\frown$	Precipitate Silt	scalar scalar	*Visual *Visual	NONE	NONE NONE	NONE	NONE	
		Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE	

Contact/Location: PAUL BECKMAN - SMLWALNC