



# FUEL REPORT

Sample Rating Trend



ISO



Machine Id  
**KIOTI VR8000121**

Component  
**Diesel Fuel**  
Fluid  
{not provided} (--- GAL)

## DIAGNOSIS

### Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KT0000980</b>	---	---
Sample Date	Client Info			<b>20 Feb 2024</b>	---	---
Machine Age	hrs	Client Info		<b>59</b>	---	---
Sample Status				<b>ABNORMAL</b>	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		<b>0.848</b>	---	---
Fuel Color	text	*Visual Screen		<b>Red</b>	---	---
ASTM Color	scalar	*ASTM D1500		<b>L4.5</b>	---	---
Visc @ 40°C	cSt	ASTM D445		<b>2.66</b>	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		<b>59</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		<b>169</b>	---	---
Sulfur (UVF)	ppm	ASTM D5453		<b>133</b>	---	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		<b>165</b>	---	---
5% Distillation Point	°C	ASTM D86		<b>197</b>	---	---
10% Distill Point	°C	ASTM D86		<b>209</b>	---	---
15% Distillation Point	°C	ASTM D86		<b>218</b>	---	---
20% Distill Point	°C	ASTM D86		<b>226</b>	---	---
30% Distill Point	°C	ASTM D86		<b>240</b>	---	---
40% Distill Point	°C	ASTM D86		<b>253</b>	---	---
50% Distill Point	°C	ASTM D86		<b>265</b>	---	---
60% Distill Point	°C	ASTM D86		<b>277</b>	---	---
70% Distill Point	°C	ASTM D86		<b>289</b>	---	---
80% Distill Point	°C	ASTM D86		<b>303</b>	---	---
85% Distillation Point	°C	ASTM D86		<b>311</b>	---	---
90% Distill Point	°C	ASTM D86		<b>321</b>	---	---
95% Distillation Point	°C	ASTM D86		<b>337</b>	---	---
Final Boiling Point	°C	ASTM D86		<b>348</b>	---	---
Distillation Residue	%	ASTM D86		<b>1.4</b>	---	---
Distillation Loss	%	ASTM D86		<b>0.4</b>	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		<b>35.4</b>	---	---
Cetane Index		ASTM D4737	<40.0	<b>46.7</b>	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.003</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>29</b>	---	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	---	---





# FUEL REPORT





FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	● 4000	---	---
Particles >6µm	ASTM D7647	>640	▲ 1560	---	---
Particles >14µm	ASTM D7647	>80	▲ 228	---	---
Particles >21µm	ASTM D7647	>20	▲ 78	---	---
Particles >38µm	ASTM D7647	>4	4	---	---
Particles >71µm	ASTM D7647	>3	1	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 19/18/15	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	---
Nickel	ppm	ASTM D5185m	<0.1	0	---
Lead	ppm	ASTM D5185m	<0.1	0	---
Vanadium	ppm	ASTM D5185m	<0.1	0	---
Iron	ppm	ASTM D5185m	<0.1	0	---
Calcium	ppm	ASTM D5185m	<0.1	0	---
Magnesium	ppm	ASTM D5185m	<0.1	0	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	---
Zinc	ppm	ASTM D5185m	<0.1	0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KT0000980 **Received** : 26 Feb 2024  
**Lab Number** : 06100577 **Tested** : 01 Mar 2024  
**Unique Number** : 10898807 **Diagnosed** : 01 Mar 2024 - Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: Screen )

**TEAM TRACTOR AND EQUIPMENT**  
 1100 W HAPPY VALLEY RD  
 PHOENIX, AZ  
 US 85085  
 Contact: MARK PEREA  
 service@teamtractor.com

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)