



# FUEL REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**MELBOURNE S1-S3**

Component  
**Diesel Fuel**  
Fluid  
{not provided} (--- GAL)

## DIAGNOSIS



### Recommendation

This is a baseline read-out on the submitted sample. Sulfur value 234 ppm derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WCDF4507</b>	---	---
Sample Date	Client Info			<b>22 Feb 2024</b>	---	---
Machine Age	mls	Client Info		<b>0</b>	---	---
Sample Status				<b>NORMAL</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur (UVF)	ppm	ASTM D5453		<b>234</b>	---	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color					no image	no image
Bottom					no image	no image



# FUEL REPORT

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WCDF4507      **Received** : 26 Feb 2024  
**Lab Number** : 06100579      **Tested** : 27 Feb 2024  
**Unique Number** : 10898809      **Diagnosed** : 27 Feb 2024 - Doug Bogart  
**Test Package** : DF-5 ( Additional Tests: Screen )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**TANK WIZARDS**  
 1511 MASTERS RD NW  
 PALM BAY, FL  
 US 32907  
 Contact: WENDALL STRODERD  
 wendall@tankwizards.com  
 T: (321)427-5149  
 F: (321)574-4131