

## **OIL ANALYSIS REPORT**

### COMPRESSOR STATIONS/ROSS DRAW AREA RIPPLE (S/N LE11602) Component

Compressor

TULCO LUBSOIL LPG WS 150 (--- GAL)

#### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. ( Customer Sample Comment: Vru PM'd two weeks ago )

#### Wear


All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		TO60002087	TO60001243	TO60000801
Sample Date		Client Info		21 Feb 2024	07 Aug 2023	05 May 2023
Machine Age	hrs	Client Info		6129	6129	3941
Oil Age	hrs	Client Info		6129	3941	2160
Oil Changed		Client Info		Not Changd	Not Changd	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	<1
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	<1	0
Lead	ppm	ASTM D5185m	>25	0	0	<1
Copper	ppm	ASTM D5185m	>50	0	<1	0
Tin	ppm	ASTM D5185m	>15	0	<1	<1
Vanadium	ppm	ASTM D5185m	210	0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	0
Barium	ppm	ASTM D5185m	0	8	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	0	<1	<1	<1
Calcium	ppm	ASTM D5185m	0	<1	0	<1
Phosphorus	ppm	ASTM D5185m	0	24	2	3
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	33	131	81
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	2
Sodium	ppm	ASTM D5185m		1	0	3
Potassium	ppm	ASTM D5185m	>20	2	<1	<1
Water	%	ASTM D6304	>2.26	0.422	0.869	0.628
ppm Water	ppm	ASTM D6304	>22600	4225	8699.2	6280
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>A</b> 31311	2999	▲ 20226
Particles >6µm		ASTM D7647	>1300	<u> </u>	918	▲ 6090
Particles >14µm		ASTM D7647	>320	<u> </u>	61	184
Particles >21µm		ASTM D7647	>80	<u> </u>	11	21
Particles >38µm		ASTM D7647	>20	2	0	1
Particles >71µm		ASTM D7647	>4	1	0	0
Oil Cleanliness		ISO 4406 (c)	>20/17/15	<u> </u>	19/17/13	▲ 22/20/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.23	0.15	0.06





# **OIL ANALYSIS REPORT**













FR.

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	151	126	121	136
Visc @ 100°C	cSt	ASTM D445	28	25.44	22.7	24.6
Viscosity Index (VI)	Scale	ASTM D2270	224	237	218	214
SAMPLE IMAGES		method	limit/base	current	history1	history2



Bottom

Color



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory

Submitted By: DEVAN SALAS

Page 2 of 2