


# **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



# 6996437 (S/N 1009)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### DIAGNOSIS

# Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr2020	Sep2020 Jun2021	Oct2021 Aug2022 Feb2023	Feb2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014251	KCP49198	KCP40680
Sample Date		Client Info		16 Feb 2024	16 Feb 2023	26 Aug 2022
Machine Age	hrs	Client Info		35779	27118	22968
Oil Age	hrs	Client Info		2000	4150	4536
Oil Changed		Client Info		Not Changd	Not Changd	Changed
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	2
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	11	11	19
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	8	2	1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	<1	1	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	24	9	4
Zinc	ppm	ASTM D5185m	0	1	15	2
Sulfur	ppm	ASTM D5185m	23500	17408	18290	18243
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	1	<1
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	1	0
Water	%	ASTM D6304	>0.05	0.004	<b>△</b> 0.186	0.020
ppm Water	ppm	ASTM D6304	>500	47	<u> </u>	203.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2392	5518	2271
Particles >6µm		ASTM D7647	>1300	802	786	432
Particles >14μm		ASTM D7647	>80	70	31	13
Particles >21µm		ASTM D7647	>20	15	7	2
Particles >38μm		ASTM D7647	>4	0	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/17/13	20/17/12	18/16/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

Contact/Location: CHRIS BALIAN - KARFRA

0.49

0.54



# **OIL ANALYSIS REPORT**





Sample No. Lab Number

: KCPA014251 : 06100962

**Unique Number** : 10899192

Received **Tested** Diagnosed : 26 Feb 2024

: 27 Feb 2024

: 28 Feb 2024 - Jonathan Hester Test Package: IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: CHRIS BALIAN - KARFRA

1376 W CENTRAL ST

Contact: CHRIS BALIAN

chris.balian@karlstorz.com

FRANKLIN, MA

US 02038

T: F: