




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**KAESER AS 20T 4648670 (S/N 1085)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA015185</b>	KCPA006156	KCP45794
Sample Date	Client Info	<b>14 Feb 2024</b>	19 Sep 2023	07 Nov 2022
Machine Age	hrs	<b>30920</b>	30194	29904
Oil Age	hrs	<b>726</b>	0	2960
Oil Changed	Client Info	<b>Changed</b>	N/A	N/A
Sample Status		<b>ATTENTION</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1	<1
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	2	▲ 2
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m >10	<b>2</b>	0	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >50	<b>5</b>	19	13
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 90	<b>23</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m 90	<b>55</b>	11	15
Calcium	ppm	ASTM D5185m 2	<b>1</b>	3	<1
Phosphorus	ppm	ASTM D5185m	<b>24</b>	4	8
Zinc	ppm	ASTM D5185m	<b>26</b>	32	38
Sulfur	ppm	ASTM D5185m	<b>19142</b>	23937	23727

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<b>0</b>	2	1
Sodium	ppm	ASTM D5185m	<b>10</b>	4	2
Potassium	ppm	ASTM D5185m >20	<b>3</b>	2	<1
Water	%	ASTM D6304 >0.05	<b>0.016</b>	▲ 0.376	▲ 0.592
ppm Water	ppm	ASTM D6304 >500	<b>165</b>	▲ 3760	▲ 5920






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>4670</b>	---	---
Particles >6µm	ASTM D7647 >1300	● <b>1731</b>	---	---
Particles >14µm	ASTM D7647 >80	● <b>127</b>	---	---
Particles >21µm	ASTM D7647 >20	● <b>25</b>	---	---
Particles >38µm	ASTM D7647 >4	<b>1</b>	---	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	● <b>19/18/14</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.37</b>	0.34	0.39

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	● LAYRD	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	▲ 0.2%
Free Water	scalar	*Visual		▲ >10%	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	46.4	47.2	47.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA015185 **Received** : 26 Feb 2024  
**Lab Number** : 06100968 **Tested** : 28 Feb 2024  
**Unique Number** : 10899198 **Diagnosed** : 28 Feb 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PriCount )

**BARE ESSENTIALS - SHISEIDO AMERICAS CORP**  
 5271 CENTER POINT CT  
 GROVEPORT, OH  
 US 43125  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)