

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER 7630824

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

A Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2023	Feb2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015882	KCPA005767	
Sample Date		Client Info		22 Feb 2024	26 Jun 2023	
Machine Age	hrs	Client Info		15295	12077	
Oil Age	hrs	Client Info		3000	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	15	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	13	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	63	4	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	23	0	
Zinc	ppm	ASTM D5185m	0	11	2	
Sulfur	ppm	ASTM D5185m	23500	18903	17521	
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		8	0	
Potassium	ppm	ASTM D5185m	>20	2	<1	
Water	%	ASTM D6304	>0.05	0.014	0.005	
ppm Water	ppm	ASTM D6304	>500	147	57.9	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10552	3378	
Particles >6µm		ASTM D7647	>1300	<u> </u>	1114	
Particles >14µm		ASTM D7647	>80	<u> </u>	32	
Particles >21µm		ASTM D7647	>20	<u> </u>	7	
Particles >38µm		ASTM D7647	>4	<mark>/</mark> 8	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 21/19/17	19/17/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.32	

Contact/Location: WEBCHECK IN CARRALNOR - WENDY SITKO - CARPIN




6000 Water 4000

6000 Nater

Built for a lifetime.

OIL ANALYSIS REPORT

В	lit for a lifetime.				
12k	Particle Trend		VISUAL		m
10k	4μm 6μm	- v	White Metal	scalar	*Vis
number of particles (1 ml) 70 kg	14μm	Y	ellow Metal	scalar	*Vis
pantic) 8k		F	Precipitate	scalar	*Vis
jo Jag			Silt	scalar	*Vis
In 2k			Debris	scalar	*Vis
0k			Sand/Dirt	scalar	*Vis
	Jun26/23	C 1	Appearance	scalar	*Vis
	۲ ۲		Ddor	scalar	*Vis
•	Water (KF)		Emulsified Water	scalar	*Vis
12000	Seyare	E F	Free Water	scalar	*Vis
10000			FLUID PROPER	TIES	m
0009 Vater (ppm)		\ 	/isc @ 40°C	cSt	AST
4000		i I	SAMPLE IMAGE	S	m
2000 0	Abnormal	_			
	Jun 26,23	Feb22/24	Color		
1.20	Acid Number				
	Base mal	E	Bottom		
(mg KOH/g) 0.96 0.72 0.48 0.48			GRAPHS		
0.48			Ferrous Alloys		
Pio 0.24		10			
0.00		8	iron		
	Jun 26/23	udd 4	nickel		
	Jum				
	Water (KF)	0.			
12000	Courses		Jun 26/23		
10000	Severe	-	2		
(m. 8000			Non-ferrous Meta	als	
(mdd) after (pbm) 4000		15	copper		
1000		_ 10	tin		_
2000	Abnormal	udd 5			
0					
	Jun26/23	VG 6473	2		********
	Viscosity @ 40°C		Jun 26/23		
60			Viscosity @ 40°C		
55	Severe	60	-		
	Abnormal	55	Severe Abnormal		
(0-0 1) tSo 45	Base	() 50 € 30 € 30 € 30 50 50 50 50 50 50 50 50 50 50 50 50 50	Base		
영 45	Abnomal		Abnormal		
40		40	Severe		
35	Severe	35	3/23		
	un 26/23	0.004	Jun26/23		
	7	4			



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory Sample No.

Contact/Location: WEBCHECK IN CARRALNOR - WENDY SITKO - CARPIN