

OIL ANALYSIS REPORT

Sample Rating Trend






ATLAS COPCO 6 NEW ATLAS (S/N APF197422)

Component Air Compressor

USPI AIR 46 (--- QTS)





DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


un'2017 Jun'2018 Aug2019 Sep2020 Aug2021 Jul'2022 Jul'2023									
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2			
Sample Number		Client Info		USPM30156	USPM29995	USPM27036			
Sample Date		Client Info		26 Feb 2024	12 Oct 2023	04 Jul 2023			
Machine Age	hrs	Client Info		0	0	0			
Oil Age	hrs	Client Info		0	0	0			
Oil Changed		Client Info		N/A	N/A	N/A			
Sample Status				ABNORMAL	NORMAL	ATTENTION			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>50	0	0	0			
Chromium	ppm	ASTM D5185m	>4	<1	0	0			
Nickel	ppm	ASTM D5185m	>4	0	0	<1			
Titanium	ppm	ASTM D5185m		0	0	0			
Silver	ppm	ASTM D5185m		0	0	0			
Aluminum	ppm	ASTM D5185m	>10	0	0	0			
Lead	ppm	ASTM D5185m	>20	0	0	0			
Copper	ppm	ASTM D5185m	>40	<1	<1	<1			
Tin	ppm	ASTM D5185m	>5	0	<1	0			
Vanadium	ppm	ASTM D5185m		0	0	0			
Cadmium	ppm	ASTM D5185m		0	0	0			
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m	0	0	0	0			
Barium	ppm	ASTM D5185m	0	0	0	0			
Molybdenum	ppm	ASTM D5185m	0	0	0	0			
Manganese	ppm	ASTM D5185m		0	<1	0			
Magnesium	ppm	ASTM D5185m	0	<1	0	0			
Calcium	ppm	ASTM D5185m	0	0	1	0			
Phosphorus	ppm	ASTM D5185m	1	2	<1	3			
Zinc	ppm	ASTM D5185m	0	3	0	0			
Sulfur	ppm	ASTM D5185m	0	0	8	0			
CONTAMINANTS	3	method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>25	0	<1	0			
Sodium	ppm	ASTM D5185m		0	0	0			
Potassium	ppm	ASTM D5185m	>20	<1	0	<1			
Water	%	ASTM D6304	>0.2	0.048	0.042	0.070			
ppm Water	ppm	ASTM D6304	>2000	490	424.1	706.4			
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2			
Particles >4µm		ASTM D7647	>10000	△ 62866	528	7752			
Particles >6µm		ASTM D7647	>2500	<u> </u>	186	▲ 2893			
Particles >14µm		ASTM D7647	>320	1184	22	299			
Particles >21µm		ASTM D7647	>80	△ 302	5	62			
Particles >38µm		ASTM D7647	>20	13	0	1			
Particles >71µm		ASTM D7647	>4	0	0	0			
Oil Cleanliness		ISO 4406 (c)	>20/18/15	23/21/17	16/15/12	▲ 20/19/15			
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2			
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.34	0.16	0.15			





OIL ANALYSIS REPORT











VISUAL		method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	NEG	
FLUID PROPERTIES method limit/base current history1 history2							
FLUID PROPERT	IES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	49.7	53.1	53.2	52.2	
SAMPLE IMAGES		method	limit/base	current	history1	history2	

Bottom

Color





GRAPHS Ferrous Alloys Particle Count 491 520 122,88 30.72 1,920 Non-ferrous Metals 480 120 Viscosity @ 40°C Acid Number (B) 0.50 NO 0.40 € 0.30 Acid Number 0.10 Abno





Certificate L2367

Laboratory Sample No. Lab Number : 06101008

: USPM30156

Unique Number: 10899238 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 26 Feb 2024 : 27 Feb 2024 **Tested**

: 27 Feb 2024 - Doug Bogart Diagnosed

TYSON - WATERLOO - USP CODE TYSWATPRO

501 N Elk Run Road Waterloo, IA US 50703

Contact: ED ALBERT

T: (319)236-9328

F: (319)236-9393

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)