


OIL ANALYSIS REPORT

LSS-9300-5 **QUINCY 91485H - PACTIV**

Component

Compressor



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	//ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06101058		
Sample Date		Client Info		05 Feb 2024		
Machine Age	hrs	Client Info		39519		
Oil Age	hrs	Client Info		2536		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
					,	, <u>, , , , , , , , , , , , , , , , , , </u>
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m		2		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		8		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		228		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		827		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.53		



42

OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	TIES	method	limit/base	current	history1	history2

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			AXCOL EMAC. SMARY ULTIFIC MORE A DISTRICT	no image	no image
Bottom				no image	no image

51.3

GRAPHS


Visc @ 40°C




cSt

ASTM D445

10 T			_ 0	opp	er	 I																				
8+		****	nen	ead																						
6-	****	~~~~	mm t	n –		ļ																				
4-																										
2 -	-						-	-		_			-	-	-		-	 	-	-	 -	_	_	_	_	
0 1	2	*****		****		***			***	-	100	***	 			-		 -			 	-884	5464	884	100	
	Feb5/24																									10111









Certificate L2367

Laboratory Sample No.

Test Package : IND 2

: UCH06101058 Lab Number : 06101058 Unique Number : 10899288

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested**

: 26 Feb 2024 : 27 Feb 2024 Diagnosed : 27 Feb 2024 - Doug Bogart

LEWIS SYSTEMS & SERVICE CO INC 9300 STOCKPORT PL

CHARLOTTE, NC US 28273

Contact: JOE KERLEY jkerley@lewissystemsinc.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (704)588-2299

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: