


OIL ANALYSIS REPORT

Sample Rating Trend



WATER



KAESER 1437284

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Feb2024		
SAMPLE INFORM	/ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006503		
Sample Date		Client Info		08 Feb 2024		
Machine Age	hrs	Client Info		19007		
Oil Age	hrs	Client Info		0		
Oil Changed	1115	Client Info		N/A		
		Ciletit IIIIO		ABNORMAL		
Sample Status				-		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	16		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	<1		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	100	1		
Calcium	ppm	ASTM D5185m	0	1		
Phosphorus	ppm	ASTM D5185m	0	0		
Zinc	ppm	ASTM D5185m	0	0		
Sulfur	ppm	ASTM D5185m	23500	16802		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304	>0.05	△ 0.059		
ppm Water	ppm	ASTM D6304	>500	▲ 590		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1175		
Particles >6µm		ASTM D7647	>1300	640		
Particles >14µm		ASTM D7647	>80	109		
Particles >21µm		ASTM D7647	>20	37		
Particles >38µm		ASTM D7647	>4	6		
Particles >71µm		ASTM D7647		1		
Oil Cleanliness		ISO 4406 (c)	>/17/13	- 17/16/14		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
		ASTM D8045		0.45		


Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.45



OIL ANALYSIS REPORT





Sample No. Lab Number

: 06101617

: KCPA006503

Tested Unique Number : 10899847

: 05 Mar 2024 : 05 Mar 2024 - Jonathan Hester Diagnosed

Test Package: IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SAN PEDRO, CA

Contact: Service Manager

US 90731

T:

F: