KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
KAESER SX 7 2562343 (S/N 1430)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation
No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of particulates present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KC127630**	KC125736	KC19270
Sample Date		Client Info		**22 Feb 2024**	30 Oct 2023	25 Mar 2009
Machine Age	hrs	Client Info		**29000**	27983	10274
Oil Age	hrs	Client Info		**0**	0	1381
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ATTENTION**	ATTENTION	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**0**	0	1
Chromium	ppm	ASTM D5185m	>10	**<1**	0	0
Nickel	ppm	ASTM D5185m		**0**	0	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	<1
Aluminum	ppm	ASTM D5185m	>25	**0**	0	<1
Lead	ppm	ASTM D5185m	>25	**0**	0	<1
Copper	ppm	ASTM D5185m	>50	**4**	4	3
Tin	ppm	ASTM D5185m	>15	**0**	0	0
Antimony	ppm	ASTM D5185m		**---**	---	<1
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m	90	**9**	0	9
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**<1**	0	<1
Magnesium	ppm	ASTM D5185m	90	**40**	22	38
Calcium	ppm	ASTM D5185m	2	**2**	0	<1
Phosphorus	ppm	ASTM D5185m		**0**	0	3
Zinc	ppm	ASTM D5185m		**10**	6	10

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**15**	16	<1
Sodium	ppm	ASTM D5185m		**9**	9	14
Potassium	ppm	ASTM D5185m	>20	**0**	0	8
Water	%	ASTM D6304	>0.1	**0.004**	0.015	0.012
ppm Water	ppm	ASTM D6304	>1000	**42**	157.4	120

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**4329**	9554	3961
Particles >6µm		ASTM D7647	>1300	**1375**	2291	2158
Particles >14µm		ASTM D7647	>80	**138**	150	367
Particles >21µm		ASTM D7647	>20	**39**	35	124
Particles >38µm		ASTM D7647	>4	**2**	1	19
Particles >71µm		ASTM D7647	>3	**0**	0	1
Oil Cleanliness		ISO 4406 (c)	>--/17/13	**19/18/14**	20/18/14	18/16

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	**0.35**	0.30	0.398

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	**44.3**	43.8	48.66

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					*no image*
Bottom					*no image*

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC127630
Lab Number : 06101625
Unique Number : 10899855
Test Package : IND 2

Received : 27 Feb 2024
Tested : 28 Feb 2024
Diagnosed : 29 Feb 2024 - Don Baldridge

KEITHLEY INSTRUMENTS
28775 AURORA ROAD
SOLON, OH
US 44139
Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: