

OIL ANALYSIS REPORT

Sample Rating Trend



KAESER SX 7 2556975 (S/N 1428)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC126681	KC97700	
Sample Date		Client Info		22 Feb 2024	30 Oct 2023	
Machine Age	hrs	Client Info		33261	33260	
Oil Age	hrs	Client Info		0	1277	
Oil Changed		Client Info		N/A	Not Changd	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m		0	0	
Lead	ppm		>10	0	0	
Copper	ppm	ASTM D5185m		2	2	
Tin	ppm		>10	0	0	
Vanadium	ppm	ASTM D5185m	210	0	0	
Cadmium		ASTM D5185m		0	0	
	ppm	ASTIVI DJIOJIII		U	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	2	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		1	<1	
Magnesium	ppm	ASTM D5185m	90	37	34	
Calcium	ppm	ASTM D5185m	2	3	0	
Phosphorus	ppm	ASTM D5185m		<1	0	
Zinc	ppm	ASTM D5185m		3	5	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	A 30	2 7	
Sodium	ppm	ASTM D5185m		4	12	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	<u> </u>	0.022	
ppm Water	ppm	ASTM D6304	>500	A 2910	220.4	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2610	3690	
Particles >6µm		ASTM D7647	>1300	<u> </u>	651	
Particles >14µm		ASTM D7647	>80	4 242	44	
Particles >21µm		ASTM D7647	>20	<u> </u>	10	
Particles >38µm		ASTM D7647	>4	1 3	1	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	 19/18/15	19/17/13	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.30	



12000

10000

8000 Water (ppm)

6000

4000

2000

4k 4k 3k 3k 2k 1k 1k

(B/HO)

Ê0.30

Ê 0.20

Pio 0.10

Built for a lifetime

OIL ANALYSIS REPORT

Water (KF)		VISUAL		method	limit/ba
Severe		White Metal	scalar	*Visual	NONE
		Yellow Metal	scalar	*Visual	NONE
		Precipitate	scalar	*Visual	NONE
		Silt	scalar	*Visual	NONE
		Debris	scalar	*Visual	NONE
Abnormal		Sand/Dirt	scalar	*Visual	NONE
0ct30/23	Feb22/24	Appearance	scalar	*Visual	NORMI
00	Feb	Odor	scalar	*Visual	NORMI
Particle Trend		Emulsified Water	scalar	*Visual	>0.05
		Free Water	scalar	*Visual	
		FLUID PROPER	TIES	method	limit/ba
νουσοσογοιου τημ.(11)		Visc @ 40°C	cSt	ASTM D445	46
	177-5886886886886868686886888888888888888	SAMPLE IMAGE	S	method	limit/ba
ann dharfer bear a dar bear barra dar barra dar barra ba					
27////CC127//	Feb 22/24 +	Color			
∽ Silicon (ppm)	LE.				
Severe		Bottom			
Abnormal		GRAPHS			
		Ferrous Alloys			
		¹⁰			4
4		8 - iron chromium			1
	Feb22/24	E 6			
	F	2			
Silicon (ppm)		L0			2/24
evere		0ct30/22			Feb22/24 s (per 1 ml
		Non-ferrous Meta	ls		articles
Abnormal		¹⁰ T			r of pa
		8 - copper			Feb22/24
3	~	2			
	10 66 41				
	L	0 ct30/23			Feb22/24
cid Number		ۃ Viscosity @ 40°C			Ľ
328		55 Abnormal			
		50 - 9			
		Base 45 Abnormal			
		40 - 9			-
	V C	35 4			Feb22/24
	ניריים	00			æ
ring	Laboratory	: WearCheck USA - 50			, NC 275
	Laboratory Sample No.)1 Madisc Rece Teste	ived : 27	



history1

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

history⁻


NEG

NEG

43.7

history2

history2



limit/base

NORML

NORML

limit/base

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

current

0.2%

NEG

43.9

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: SERVICE MANAGER ? - KEISOL