


# **FUEL REPORT**

### Sample Rating Trend



**NORMAL** 



# HF HOSPICE HOUSE

Component

**Diesel Fuel** 

No.2 DIESEL FUEL (ULTRALOW SULPHUR

#### Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

#### **Contaminants**

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel.


#### **Fuel Condition**

Sulfur value derived by ASTM D5453 method for ULSD validation.

R) (939 GAL)			Mar2023	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WCDF4528	WCDF4333	
Sample Date		Client Info		11 Mar 2024	16 Mar 2023	
Machine Age	mls	Client Info		0	0	
Sample Status				NORMAL	ABNORMAL	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	0.839		0.844	
Fuel Color	text	*Visual Screen	Yllow	Red	Red	
ASTM Color	scalar	*ASTM D1500		L4.5	L4.0	
Visc @ 40°C	cSt	ASTM D445	3.0	2.73	2.48	
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	64.9	62	
Cloud Point	°C	ASTM D5771		-12	-13	
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	31	0	
Sulfur (UVF)	ppm	ASTM D5453		21	13	
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	176	171	
5% Distillation Point	°C	ASTM D86		199	193	
10% Distill Point	°C	ASTM D86	201	209	205	
15% Distillation Point	°C	ASTM D86	201	218	215	
20% Distill Point	°C	ASTM D86	216	226	223	
30% Distill Point	°C	ASTM D86	230	241	239	
40% Distill Point	°C	ASTM D86	243	254	254	
50% Distill Point	°C	ASTM D86	255	268	268	
60% Distill Point	°C	ASTM D86	267	281	282	
70% Distill Point	°C	ASTM D86	280	295	296	
80% Distill Point	°C	ASTM D86	295	310	311	
85% Distillation Point	°C	ASTM D86	293	320	319	
90% Distill Point	°C	ASTM D86	310	329	329	
95% Distillation Point		ASTM D86	310	344	345	
Final Boiling Point	°C	ASTM D86	341	358	352	
Distillation Residue	%	ASTM D86	3.0		1.4	
Distillation Loss	%	ASTM D86	3.0		0.8	
IGNITION QUALIT		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	35.9	36.2	
Cetane Index		ASTM D4737	<40.0	48	48.4	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	1	
Sodium	ppm	ASTM D5185m	<0.1	<1	<1	
Potassium	ppm	ASTM D5185m	<0.1	<1	0	
Water	%	ASTM D6304	< 0.05	0.003	0.006	
ppm Water	ppm	ASTM D6304	<500	31	69.5	
% Gasoline	%	*In-House	<0.50	0.0	0.0	
% Biodiesel	%	*In-House	<20.0	0.0	1.6	
	, •	1.0000		5.5		



## **FUEL REPORT**





Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WCDF4528 Lab Number : 06121301

Unique Number: 10930134

Received : 18 Mar 2024 **Tested** : 01 Apr 2024 Diagnosed

: 01 Apr 2024 - Doug Bogart Test Package: DF-2 (Additional Tests: CldPt, Fuel, Screen)

Contact: WENDALL STRODERD wendall@tankwizards.com

T: (321)427-5149

1511 MASTERS RD NW

**TANK WIZARDS** 

PALM BAY, FL

F: (321)574-4131

US 32907

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)