




# FUEL REPORT

## Sample Rating Trend



WATER



Machine Id  
**VIERA TANK 1**

Component  
**Diesel Fuel**  
Fluid

**No.2 DIESEL FUEL (ULTRALOW SULPHUR) (10000 GAL)**

### DIAGNOSIS

#### ▲ Recommendation

We advise that you follow the water drain-off procedure for this component. All other laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel. Please note that this is a corrected copy for laboratory data and diagnostic comment updates.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

#### ▲ Contaminants

Excessive free water present. There is no bacteria or fungus (yeast and/or mold) present in the sample.

#### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WCDF4539</b>	WCDF4343	---
Sample Date	Client Info		<b>12 Mar 2024</b>	16 Mar 2023	---
Machine Age	mls	Client Info	<b>0</b>	0	---
Sample Status			<b>SEVERE</b>	SEVERE	---

### PHYSICAL PROPERTIES

	method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.839	---	0.839	---
Fuel Color	text	*Visual Screen	Yellow	<b>Red</b>	Red
ASTM Color	scalar	*ASTM D1500		<b>L4.5</b>	L4.0
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.36</b>	2.6
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	<b>64.5</b>	62
Cloud Point	°C	ASTM D5771		<b>-11</b>	-11

### SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	<b>24</b>	0
Sulfur (UVF)	ppm	ASTM D5453		<b>19</b>	51

### DISTILLATION

	method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	<b>176</b>	170
5% Distillation Point	°C	ASTM D86		<b>198</b>	194
10% Distill Point	°C	ASTM D86	201	<b>207</b>	205
15% Distillation Point	°C	ASTM D86		<b>215</b>	213
20% Distill Point	°C	ASTM D86	216	<b>222</b>	220
30% Distill Point	°C	ASTM D86	230	<b>236</b>	234
40% Distill Point	°C	ASTM D86	243	<b>249</b>	248
50% Distill Point	°C	ASTM D86	255	<b>262</b>	262
60% Distill Point	°C	ASTM D86	267	<b>276</b>	275
70% Distill Point	°C	ASTM D86	280	<b>289</b>	289
80% Distill Point	°C	ASTM D86	295	<b>304</b>	305
85% Distillation Point	°C	ASTM D86		<b>315</b>	315
90% Distill Point	°C	ASTM D86	310	<b>325</b>	326
95% Distillation Point	°C	ASTM D86		<b>343</b>	344
Final Boiling Point	°C	ASTM D86	341	<b>358</b>	352
Distillation Residue	%	ASTM D86	3.0	---	1.4
Distillation Loss	%	ASTM D86	3.0	---	0.8

### IGNITION QUALITY





	method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	<b>37.3</b>	37.2	---
Cetane Index	ASTM D4737	<40.0	<b>50</b>	49.5	---

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	<1
Sodium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	<1
Potassium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	0
Water	%	ASTM D6304	<0.05	<b>0.005</b>	0.005
ppm Water	ppm	ASTM D6304	<500	<b>52</b>	55.4
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	0.0
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	0.0






# FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	<1	---
Nickel	ppm	ASTM D5185m	<0.1	0	0	---
Lead	ppm	ASTM D5185m	<0.1	0	0	---
Vanadium	ppm	ASTM D5185m	<0.1	0	<1	---
Iron	ppm	ASTM D5185m	<0.1	0	0	---
Calcium	ppm	ASTM D5185m	<0.1	<1	0	---
Magnesium	ppm	ASTM D5185m	<0.1	<1	4	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	▲ 6	---
Zinc	ppm	ASTM D5185m	<0.1	0	0	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						no image
Bottom						no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WCDF4539 **Received** : 18 Mar 2024  
**Lab Number** : 06121305 **Tested** : 03 Apr 2024  
**Unique Number** : 10930138 **Diagnosed** : 03 Apr 2024 - Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: CldPt, Fuel, Screen )

**TANK WIZARDS**  
 1511 MASTERS RD NW  
 PALM BAY, FL  
 US 32907  
 Contact: WENDALL STRODERD  
 wendall@tankwizards.com  
 T: (321)427-5149  
 F: (321)574-4131

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)