




# COOLANT REPORT

Sample Rating Trend

**NORMAL**



Area  
**OKLAHOMA/1151/EG - LOADER**  
 Machine Id  
**46.87L [OKLAHOMA^1151^EG - LOADER]**  
 Component  
**Coolant**  
 Fluid  
**CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)**



## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.

### Coolant Condition

Carboxylate test failed. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0886927</b>	WC0848863	WC0778323
Sample Date	Client Info		<b>13 Mar 2024</b>	11 Sep 2023	19 May 2023
Machine Age	hrs	Client Info	<b>10197</b>	9318	8712
Oil Age	hrs	Client Info	<b>500</b>	500	500
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		<b>1.070</b>	1.069	1.068
pH	Scale 0-14	ASTM D1287	<b>7.59</b>	7.47	7.40
Nitrites	ppm	AP-053:2009	<b>600</b>	448	300
Reserve Alkalinity	Scale 0-20	*ASTM D1121	---	---	---
Percentage Glycol	%	ASTM D3321	<b>52.0</b>	51.3	50.9
Freezing Point	°F	ASTM D3321	<b>-40</b>	-38	-35
Total Dissolved Solids			<b>316.0</b>	376.0	357.5
Carboxylate			<b>fail</b>	fail	pass

## CORROSION INHIBITORS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D6130	0	<b>20</b>	42	42
Phosphorus	ppm	ASTM D6130	0	<b>&lt;1</b>	0	2
Boron	ppm	ASTM D6130	0	<b>0</b>	8	3
Molybdenum	ppm	ASTM D6130	950	<b>629</b>	1023	1050

## CORROSION

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D6130	>15	<b>3</b>	<1	0
Aluminum	ppm	ASTM D6130	>10	<b>1</b>	3	2
Copper	ppm	ASTM D6130	>10	<b>&lt;1</b>	1	1
Lead	ppm	ASTM D6130	>10	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D6130	>10	<b>0</b>	<1	0
Zinc	ppm	ASTM D6130		<b>0</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Chlorine	ppm	ASTM D6130		<b>10</b>	20	9

## CARRIER SALTS


	method	limit/base	current	history1	history2	
Sodium	ppm	ASTM D6130		<b>3906</b>	5937	5481
Potassium	ppm	ASTM D6130		<b>104</b>	180	207

## SCALE POTENTIAL

	method	limit/base	current	history1	history2	
Calcium	ppm	ASTM D6130		<b>2</b>	5	4
Magnesium	ppm	ASTM D6130		<b>1</b>	3	3









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	Red	Orange
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0886927 **Received** : 18 Mar 2024  
**Lab Number** : 06121322 **Tested** : 20 Mar 2024  
**Unique Number** : 10930155 **Diagnosed** : 20 Mar 2024 - Jonathan Hester  
**Test Package** : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP )

**SHERWOOD CONSTRUCTION CO INC**  
 3219 WEST MAY ST  
 WICHITA, KS  
 US 67213  
 Contact: DOUG KING  
 doug.king@sherwood.net  
 T: (316)617-3161  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)