

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id KAESER SFC 55 6540684 (S/N 1132)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2019	Dec2019 Jan2021	Nov2021 Aug2022 M	ay2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC111316	KC111623	KC105815
Sample Date		Client Info		22 Aug 2023	25 May 2023	04 Jan 2023
Machine Age	hrs	Client Info		30501	28351	25077
Oil Age	hrs	Client Info		0	6101	2821
Oil Changed		Client Info		Changed	Not Changd	Not Changd
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	4	11
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	3	6
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		8	7	0
Zinc	ppm	ASTM D5185m		26	61	79
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		1	2	11
Potassium	ppm	ASTM D5185m	>20	0	1	<1
Water	%	ASTM D6304	>0.05	0.004	△ 0.100	0.011
ppm Water	ppm	ASTM D6304	>500	48	△ 1000	114.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		2284		
Particles >6µm		ASTM D7647	>1300	692		
Particles >14µm		ASTM D7647	>80	46		
Particles >21µm		ASTM D7647	>20	12		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/17/13		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.47	0.46	0.39



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number

Unique Number: 10930445 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC111316 Received : 18 Mar 2024 : 06121612 **Tested** : 21 Mar 2024

Diagnosed

: 21 Mar 2024 - Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

BARD MANUFACTURING

Contact: Service Manager

1914 RANDOLPH DR

BRYAN, OH

US 43506

T:

F: