

OIL ANALYSIS REPORT

RC-5 (S/N 0575)

Refrigeration Compressor

FRICK COMPRESSOR OIL #11 (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Oct2023	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0006075	USP0003002	
Sample Date		Client Info		17 Mar 2024	16 Oct 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	3	2	
Chromium	ppm	ASTM D5185m	>2	0	<1	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	<1	
Lead	ppm	ASTM D5185m	>2	0	0	
Copper	ppm	ASTM D5185m	>8	0	<1	
Tin	ppm	ASTM D5185m	>4	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		0	0	
Zinc	ppm	ASTM D5185m		4	2	
Sulfur	ppm	ASTM D5185m		0	0	
CONTAMINANTS)	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	1	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	0	1	
Water	%	ASTM D6304	>0.01	0.001	0.015	
ppm Water	ppm	ASTM D6304	>100	11	150	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	140664	<u>▲</u> 161325	
Particles >6µm		ASTM D7647	>2500	<u>^</u> 29319	▲ 33308	
Particles >14μm		ASTM D7647	>320	178	301	
Particles >21µm		ASTM D7647	>80	17	31	
Particles >38μm		ASTM D7647	>20	0	1	
Particles >71μm		ASTM D7647	>4	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>4</u> 24/22/15	<u>\$\text{\Delta}\$ 25/22/15</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974		0.014	0.015	



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number

: USP0006075 : 06121628

Unique Number: 10930461 Test Package : IND 2

Received **Tested** : 21 Mar 2024 Diagnosed

: 21 Mar 2024 - Doug Bogart

2281 STEELE STATION RD

RAINBOW CITY, AL US 35906

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: