


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



FRICK FRICK 7 (S/N TOSH2933S29390E)

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Jul2021	Jan2022 Jul2022	Jan2023 Jun2023 De	c2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0006086	USP0004549	USP0001954
Sample Date		Client Info		17 Mar 2024	28 Dec 2023	18 Sep 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	0	3
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	<1
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	1	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	3	4	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	1
Sodium	ppm	ASTM D5185m		0	1	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	<1
Water	%	ASTM D6304	>0.01	0.001	0.003	0.003
ppm Water	ppm	ASTM D6304	>100	10	28	39.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		441	891	1053
Particles >6µm		ASTM D7647	>2500	113	327	246
Particles >14µm		ASTM D7647	>320	11	66	17
Particles >21µm		ASTM D7647	>80	3	23	5
Particles >38µm		ASTM D7647	>20	0	0	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	16/14/11	17/16/13	17/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.013	0.014	0.014





OIL ANALYSIS REPORT



3k - 4μm 6μm 14μm		Λ	
5k		/\	
	~		








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIEC	mathad	limit/bass	Olivropt.	historyt	history
FLUID PROPER	TES	method				history2

I LOID I HOI LITT	ILO					
Visc @ 40°C	cSt	ASTM D445	65.6	62.8	62.7	62.8

SAIVIFLE IIVIAGES	memou	

Bottom

Color



Ferrous Alloys Particle Count 491 520 122,880 30,720 7,680 1,920 Non-ferrous Metals 480 120 Viscosity @ 40°C Acid Number 20.0 20.0 10.0 10.0 0.01 55 Jun15/23





Certificate L2367

Laboratory Sample No. Lab Number : 06121636

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0006086

Unique Number : 10930469

Received **Tested**

: 18 Mar 2024 : 20 Mar 2024 Diagnosed

: 20 Mar 2024 - Doug Bogart

TYSON PF-HUTCHINSON-USP

521 SOUTH MAIN HUTCHINSON, KS US 67501

T: (620)669-8761

F: (620)669-8762

Contact: ERIC JOHNSON

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)