


OIL ANALYSIS REPORT

Sample Rating Trend





Machine Id **3K-3**Component

Compressor

HP R&O ISO 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2023	Jul2023 Sep2023	Nov2023 Jan2024	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		HPL0004542	HPL0004514	HPL0002601
Sample Date		Client Info		13 Mar 2024	15 Feb 2024	11 Jan 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	2	3
Chromium	ppm	ASTM D5185m	>10	0	<1	<1
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	2	2
Lead	ppm	ASTM D5185m	>25	1	<1	2
Copper	ppm	ASTM D5185m	>50	4	6	8
Tin	ppm	ASTM D5185m	>15	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		2	<1	1
Calcium	ppm	ASTM D5185m		4	4	8
Phosphorus	ppm	ASTM D5185m		102	112	164
Zinc	ppm	ASTM D5185m		<1	6	0
Sulfur	ppm	ASTM D5185m		10380	9225	12469
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	1
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	2	1	<1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.44

Acid Number (AN)

mg KOH/g ASTM D8045

0.41

0.32




90

OIL ANALYSIS REPORT

cSt

ASTM D445

Visc @ 40°C



VISUAL		method	limit/base	current	history1	history2	
White Metal sca		*Visual	NONE	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE	
Appearance scalar		*Visual	NORML	NORML	NORML	NORML	
Odor sca		*Visual	NORML	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	NEG	
FLUID PROPERTIES		method	limit/base	current	history1	history2	

112

112

111

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			no image	no image	no image
Bottom			no image	no image	no image
GRAPHS					

	GRAP	HS												
	Iron (p	opm)					Lead (ppm)							
200	Severe						Severe							
튭 100	Abnormal						Abnormal							
0	23	23	23	23	24	24	23 0	23	23	23	24	24		
	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24		
	Alumir	num (p	pm)				Chromi	um (p	pm)					
100	Severe						30 Severe							
Ed 50	Abnormal						Abnormal	-	-		 			
0	23	23	23	23	24	24	23 0	23	23	23	24	24		
	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24		
	Copper (ppm)						Silicon (ppm)							
200	Severe						Severe							
튭 100	Abnormal						Abnormal							
0	23	23	23	23	24	24	23 0	23	23	23	24	24		
	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24		
	Viscos	ity @ 4	10°C											
200-	Abnorma						Acid Number (mg KOH/g)							
cSt (40°C)	Abnormal					-	e 0.20							
0	23	23 +	- 53	23	24	24	23 00.00 Ni	23	23	23	24	24		
	May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24	Acii May15/23	Jul13/23	Sep14/23	Nov15/23	Jan11/24	Mar13/24		





Certificate L2367

Lab Number : 06121706 Unique Number : 10930539

Sample No. : HPL0004542

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested**

: 18 Mar 2024 : 19 Mar 2024

: 19 Mar 2024 - Wes Davis

MARATHON PETROLEUM CO.

IL. REFININF DIVISION, 400 S MARATHON AVE ROBINSON, IL US 62454

Contact: M.S. MANHART

Test Package : MOB 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

mmanhart@marathonpetroleum.com T: (618)544-2121

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

F: x: