


OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER SM 10 7181402 (S/N 1281)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- LTR)

DIAGNOSIS

▲ **Recommendation**

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ **Contamination**

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | KC06122325 | KC05656267 | KC05301264 |
| Sample Date | Client Info | | 16 Feb 2024 | 08 Sep 2022 | 02 Jul 2021 |
| Machine Age | hrs | Client Info | 4973 | 3039 | 1254 |
| Oil Age | hrs | Client Info | 0 | 693 | 1254 |
| Oil Changed | Client Info | | N/A | Changed | Changed |
| Sample Status | | | ABNORMAL | NORMAL | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >50 | 0 | 0 | <1 |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m >10 | 0 | <1 | 0 |
| Lead | ppm | ASTM D5185m >10 | <1 | <1 | <1 |
| Copper | ppm | ASTM D5185m >50 | 7 | 5 | 1 |
| Tin | ppm | ASTM D5185m >10 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|----------------|----------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | 13 |
| Barium | ppm | ASTM D5185m 90 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m 90 | 1 | 28 | 53 |
| Calcium | ppm | ASTM D5185m 2 | 0 | 0 | <1 |
| Phosphorus | ppm | ASTM D5185m | 0 | 4 | 5 |
| Zinc | ppm | ASTM D5185m | 0 | 6 | 4 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | 0 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | 3 | 6 | 12 |
| Potassium | ppm | ASTM D5185m >20 | 0 | 5 | 6 |
| Water | % | ASTM D6304 >0.05 | ▲ 0.178 | 0.025 | ▲ 0.065 |
| ppm Water | ppm | ASTM D6304 >500 | ▲ 1780 | 254.9 | ▲ 653.0 |






FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|------------------|------------|-------------------|----------|----------|
| Particles >4µm | ASTM D7647 | | 1366 | 1596 | 13737 |
| Particles >6µm | ASTM D7647 >1300 | | 744 | 546 | ▲ 5442 |
| Particles >14µm | ASTM D7647 >80 | | ● 127 | 32 | 71 |
| Particles >21µm | ASTM D7647 >20 | | ● 43 | 8 | 12 |
| Particles >38µm | ASTM D7647 >4 | | ● 7 | 1 | 0 |
| Particles >71µm | ASTM D7647 >3 | | 1 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >--/17/13 | ● 18/17/14 | 18/16/12 | ▲ 20/13 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|----------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.4 | 0.31 | 0.27 | 0.325 |


OIL ANALYSIS REPORT





| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | ▲ 0.2% | NEG |
| Free Water | scalar | *Visual | | ▲ NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | 43.5 | 43.5 | 44.0 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : KC06122325
 Lab Number : 06122325
 Unique Number : 10936476
 Test Package : IND 2
 Received : 19 Mar 2024
 Tested : 25 Mar 2024
 Diagnosed : 25 Mar 2024 - Don Baldrige

UNIVERSITY TIRE
 1170 MITCHELL BRIDGE RD
 ATHENS, GA
 US 30606
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)