




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**BUSCH CV1 WEST TENDER SECONDARY (S/N 5598119)**

Component  
**Vacuum Pump**

Fluid  
**USPI VAC 100 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USPM30476</b>	USPM31825	USP242060
Sample Date	Client Info	<b>18 Mar 2024</b>	10 Dec 2023	13 Sep 2023
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	<b>9</b>	15	16
Chromium	ppm	ASTM D5185m >20	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>2</b>	2	2
Lead	ppm	ASTM D5185m >20	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >20	<b>0</b>	<1	1
Tin	ppm	ASTM D5185m >20	<b>1</b>	0	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	<1

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	<b>&lt;1</b>	1	2
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	<1	0
Calcium	ppm	ASTM D5185m 0	<b>0</b>	5	4
Phosphorus	ppm	ASTM D5185m 1800	<b>758</b>	735	767
Zinc	ppm	ASTM D5185m 0	<b>37</b>	27	34
Sulfur	ppm	ASTM D5185m 0	<b>0</b>	0	31

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<b>16</b>	13	11
Sodium	ppm	ASTM D5185m	<b>3</b>	5	5
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	4
Water	%	ASTM D6304 >.1	<b>0.022</b>	0.043	0.009
ppm Water	ppm	ASTM D6304 >1000	<b>229</b>	437	99.6

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>570</b>	1400	---
Particles >6µm	ASTM D7647 >1300	<b>180</b>	493	---
Particles >14µm	ASTM D7647 >160	<b>18</b>	41	---
Particles >21µm	ASTM D7647 >40	<b>3</b>	9	---
Particles >38µm	ASTM D7647 >10	<b>0</b>	1	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>16/15/11</b>	18/16/13	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	<b>0.92</b>	1.207	1.14




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 91	96.4	97.6	97.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : USPM30476  
 Lab Number : 06122430  
 Unique Number : 10936581  
 Test Package : IND 2

Received : 19 Mar 2024  
 Tested : 20 Mar 2024  
 Diagnosed : 20 Mar 2024 - Doug Bogart

**JBS-OTTUMWA**  
 600 SOUTH IOWA AVENUE  
 OTTUMWA, IA  
 US 52501  
 Contact: LISA PIERCE  
 lisa\_pierce@cargill.com  
 T: (641)683-4741  
 F: (641)683-4731

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)