

OIL ANALYSIS REPORT

Kenova [Kenova] Oil - Port Reduction Gear

Port Reduction Gear

Reduction Gear Oil (35 GAL)

Sample Rating Trend



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0859753	WC0805209	WC0805221
Sample Date		Client Info		11 Mar 2024	16 Jan 2024	20 Nov 2023
Machine Age	hrs	Client Info		40248	39022	37876
Oil Age	hrs	Client Info		3058	1842	690
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	7	7	5
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>10	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>50	0	<1	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
=	pp	710 1111 20 100111		·	O	O .
ADDITIVES	PP	method	limit/base	current	history1	history2
	ppm		limit/base			history2
ADDITIVES		method	limit/base	current	history1	history2
ADDITIVES Boron	ppm	method ASTM D5185m	limit/base	current	history1	history2
ADDITIVES Boron Barium	ppm	method ASTM D5185m ASTM D5185m	limit/base	current 7 0	history1 7 0	history2 3 0
ADDITIVES Boron Barium Molybdenum	ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	current 7 0 11	history1 7 0 12	history2 3 0 10
ADDITIVES Boron Barium Molybdenum Manganese	ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	current 7 0 11	history1 7 0 12 <1	history2 3 0 10 <1
ADDITIVES Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	current 7 0 11 0 216	history1 7 0 12 <1 207	history2 3 0 10 <1 205
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base	current 7 0 11 0 216 3299	history1 7 0 12 <1 207 3316	history2 3 0 10 <1 205 3280 873 954
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base	current 7 0 11 0 216 3299 840	history1 7 0 12 <1 207 3316 891	history2 3 0 10 <1 205 3280 873
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base	current 7 0 11 0 216 3299 840 897	history1 7 0 12 <1 207 3316 891 987	history2 3 0 10 <1 205 3280 873 954
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m		current 7 0 11 0 216 3299 840 897 9580	history1 7 0 12 <1 207 3316 891 987 8968	history2 3 0 10 <1 205 3280 873 954 8358
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base	current 7 0 11 0 216 3299 840 897 9580 current	history1 7 0 12 <1 207 3316 891 987 8968 history1	history2 3 0 10 <1 205 3280 873 954 8358 history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base	current 7 0 11 0 216 3299 840 897 9580 current 3 <1 0	history1 7 0 12 <1 207 3316 891 987 8968 history1	history2 3 0 10 <1 205 3280 873 954 8358 history2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base >50 >20	current 7 0 11 0 216 3299 840 897 9580 current 3 <1	history1 7 0 12 <1 207 3316 891 987 8968 history1 4	history2 3 0 10 <1 205 3280 873 954 8358 history2 3 2
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base >50 >20	current 7 0 11 0 216 3299 840 897 9580 current 3 <1 0	history1 7 0 12 <1 207 3316 891 987 8968 history1 4 1 <1	history2 3 0 10 <1 205 3280 873 954 8358 history2 3 2 <1
ADDITIVES Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium Water	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	limit/base >50 >20 >0.1	current 7 0 11 0 216 3299 840 897 9580 current 3 <1 0 0.014	history1 7 0 12 <1 207 3316 891 987 8968 history1 4 1 <1 0.026	history2 3 0 10 <1 205 3280 873 954 8358 history2 3 2 <1 0.033



OIL ANALYSIS REPORT








VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPER	RTIES	method			history?
Visc @ 40°C	cSt	ASTM D445	115	117	120


SAMPLE IMAGES method lin		t history1 histor	
--------------------------	--	-------------------	--


Color







GRAPHS













Certificate L2367

Laboratory Sample No.

Lab Number : 06122466

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0859753

Received **Tested** Unique Number: 10936617 Test Package : IND 2 (Additional Tests: KF)

: 19 Mar 2024 : 20 Mar 2024 Diagnosed

: 21 Mar 2024 - Don Baldridge

MARATHON PETROLEUM CO.

101 12TH ST CATLETTSBURG, KY US 41169

Contact: CORY GUMBERT cagumbert@marathonpetroleum.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (606)585-3950 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: x: