


## **OIL ANALYSIS REPORT**

# Area [603901767 SDR]

L-5 FOILER 3 MD (S/N 20076711)

Gearbox

FIRE-RESISTANT FLUID ISO 68 (--- GAL)





#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.


### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0854602	WC0605562	WC0605204
Sample Date		Client Info		29 Feb 2024	29 Mar 2023	19 Mar 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	0	0	<1
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	<1	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Antimony	ppm	ASTM D5185m	>5			
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	<1
Barium	ppm	ASTM D5185m	5	0	0	0
Malubdanum						
Molybdenum	ppm	ASTM D5185m	5	0	0	0
Manganese	ppm ppm	ASTM D5185m ASTM D5185m	5	0	0 <1	0
•			5		_	
Manganese	ppm	ASTM D5185m		0	<1	0
Manganese Magnesium	ppm	ASTM D5185m ASTM D5185m	5	0	<1 2	0
Manganese Magnesium Calcium	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	5 50	0 0 0	<1 2 0	0 0
Manganese Magnesium Calcium Phosphorus	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	5 50 175	0 0 0 175	<1 2 0 198	0 0 0 198
Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	5 50 175 62	0 0 0 175	<1 2 0 198 2	0 0 0 198
Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	5 50 175 62 500	0 0 0 175 0 1945	<1 2 0 198 2 2188	0 0 0 198 0 1300
Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	5 50 175 62 500 limit/base	0 0 0 175 0 1945	<1 2 0 198 2 2188 history1	0 0 0 198 0 1300 history2
Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method ASTM D5185m	5 50 175 62 500 limit/base	0 0 0 175 0 1945 current	<1 2 0 198 2 2188 history1	0 0 198 0 1300 history2
Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m Method ASTM D5185m ASTM D5185m	5 50 175 62 500 limit/base >50	0 0 0 175 0 1945 current 2	<1 2 0 198 2 2188 history1 3	0 0 198 0 1300 history2
Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	5 50 175 62 500 limit/base >50	0 0 0 175 0 1945 current 2 0	<1 2 0 198 2 2188 history1 3 0 <1	0 0 198 0 1300 history2 10 0



## **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>55	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERT	TES	method				history
Visc @ 40°C	cSt	ASTM D445	68	66.7	66.5	64.6


SAMPLE	IMAGES	


Color


**Bottom** 


















Laboratory Sample No. Lab Number : 06122556 Unique Number : 10936707

: WC0854602

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** 

Diagnosed

: 21 Mar 2024

: 19 Mar 2024

: 21 Mar 2024 - Jonathan Hester Test Package : IND 2 ( Additional Tests: KF, pH, ReserveAlk )

Contact: TONY FIORE tony.fiore@effem.com T: (773)745-2279

MARS CHOCOLATE

CHICAGO, IL

US 60707

2019 NORTH OAK PARK

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: Contact/Location: TONY FIORE - MARSCHI