




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
Tri State
 Machine Id
[Tri State] Oil - Starboard Genset
 Component
Starboard Genset
 Fluid
DIESEL ENGINE OIL SAE 15W40 (5 GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0859809	WC0845871	WC0769592
Sample Date	Client Info	26 Feb 2024	26 Jan 2024	22 Dec 2023
Machine Age	hrs	21942	13293	12887
Oil Age	hrs	1243	346	264
Oil Changed	Client Info	Changed	Changed	Changed
Sample Status		NORMAL	NORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >4.0	<1.0	<1.0	<1.0
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	6	7	2
Chromium	ppm ASTM D5185m >4	0	<1	1
Nickel	ppm ASTM D5185m >2	0	0	0
Titanium	ppm ASTM D5185m	0	<1	0
Silver	ppm ASTM D5185m >5	0	0	0
Aluminum	ppm ASTM D5185m >12	0	<1	2
Lead	ppm ASTM D5185m >17	0	0	0
Copper	ppm ASTM D5185m >70	1	1	0
Tin	ppm ASTM D5185m >15	0	0	0
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 250	7	8	6
Barium	ppm ASTM D5185m 10	0	0	4
Molybdenum	ppm ASTM D5185m 100	58	63	68
Manganese	ppm ASTM D5185m	0	<1	0
Magnesium	ppm ASTM D5185m 450	1456	1470	1472
Calcium	ppm ASTM D5185m 3000	1153	1125	1174
Phosphorus	ppm ASTM D5185m 1150	964	1091	1124
Zinc	ppm ASTM D5185m 1350	1243	1330	1302
Sulfur	ppm ASTM D5185m 4250	3729	3497	4015

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	3	4	0
Sodium	ppm ASTM D5185m >158	0	1	0
Potassium	ppm ASTM D5185m >20	0	0	0
Water	% ASTM D6304 >0.1	NEG	NEG	NEG

INFRA-RED




method	limit/base	current	history1	history2
Soot %	% *ASTM D7844	0.6	0.1	0.8
Nitration	Abs/cm *ASTM D7624 >20	7.8	7.1	8.1
Sulfation	Abs/.1mm *ASTM D7415 >30	20.4	19.8	21.1

FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414 >25	16.3	15.9	16.4
Base Number (BN)	mg KOH/g ASTM D2896 8.5	12.90	12.22	13.33







OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	14.4	13.1	13.3	13.49

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0859809
Lab Number : **06122616**
Unique Number : 10936767
Test Package : IND 2 (Additional Tests: KF)

MARATHON PETROLEUM CO.
 101 12TH ST
 CATLETTSBURG, KY
 US 41169
 Contact: CORY GUMBERT
 cagumbert@marathonpetroleum.com
 T: (606)585-3950
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)