


FUEL REPORT

[PMIAS3286683] GENERAC 10475170100 2100972

Diesel Fuel

No.2 DIESEL FUEL (LOW-SULPHUR) (9 GAL)





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.


AL)		Feb 2019	Jan 2020	Jan2022 Mar2023	Feb 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		DC0034692	DC0025198	DC0014142
Sample Date		Client Info		23 Feb 2024	21 Mar 2023	12 Jan 2022
Machine Age	hrs	Client Info		615	590	560
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL PROF	PERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L2.5	L1.5	L1.0
Visc @ 40°C	cSt	ASTM D445	3.0	2.46	2.57	2.5
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	250	0	0	19
Sulfur (UVF)	ppm	ASTM D5453		15	18	18
IGNITION QUALI	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36.7		36.5
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	2	1	0
Sodium	ppm	ASTM D5185m	<0.1	<1	0	0
Potassium	ppm	ASTM D5185m	< 0.1	0	<1	0
Water	%	ASTM D6304	< 0.05	0.001	0.004	0.002
ppm Water	ppm	ASTM D6304	< 500	8	40.3	25.0
% Gasoline	%	*In-House	< 0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500		1826	711
Particles >6µm		ASTM D7647	>640		623	280
Particles >14µm		ASTM D7647	>80		56	43
Particles >21µm		ASTM D7647	>20		12	10
Particles >38µm		ASTM D7647	>4		1	0
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13		18/16/13	17/15/13
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	< 0.1	0	0	0
Nickel	ppm	ASTM D5185m	< 0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	0	0
Vanadium	ppm	ASTM D5185m	<0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	0	0	0
Calcium	ppm	ASTM D5185m	<0.1	0	<1	0
Magnesium	ppm	ASTM D5185m	<0.1	0	0	0
Phosphorus	ppm	ASTM D5185m	<0.1	0	1	1
Zinc	ppm	ASTM D5185m	< 0.1	0	0	0




FUEL REPORT











Certificate 12367

Report Id: KELOWI [WUSCAR] 06122861 (Generated: 04/07/2024 16:19:09) Rev: 1

Laboratory

Sample No. : DC0034692 Lab Number : 06122861 Unique Number : 10937012

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Tested

Received : 19 Mar 2024 Diagnosed

: 07 Apr 2024

: 07 Apr 2024 - Doug Bogart Test Package: DF-5 (Additional Tests: API, Cetane, Fuel, Screen)

KELLY GENERATOR & EQUIPMENT INC 1955 DALE LN OWINGS, MD US 20736 Contact: LESLIE SNURR

LSNURR@KGE.COM T: (410)257-5225 F: (410)257-5227

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: LESLIE SNURR - KELOWI