




# COOLANT REPORT

Sample Rating Trend



## APPEARANCE



Area

**Kenova**

Machine Id

**[Kenova] Coolant - Port Main Engine (Jacket)**

Component

**Coolant**

Fluid

**CATERPILLAR ELC (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

We recommend drain/flush system, and refill with 50/50 antifreeze water mixture. We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer's recommendations. ( Customer Sample Comment: Coolant )

#### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

#### ▲ Contaminants

Sediment present.

#### Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0805212</b>	WC0735187	WC0719157
Sample Date	Client Info		<b>11 Mar 2024</b>	14 Feb 2023	25 Oct 2022
Machine Age	hrs	Client Info	<b>40128</b>	32792	30630
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

### PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		<b>1.052</b>	1.055	1.055
pH	Scale 0-14	ASTM D1287	<b>7.52</b>	7.84	7.91
Nitrites	ppm	AP-053:2009	<b>448</b>	712	600
Reserve Alkalinity	Scale 0-20	*ASTM D1121	---	---	---
Percentage Glycol	%	ASTM D3321	<b>38.3</b>	40.3	40.2
Freezing Point	°F	ASTM D3321	<b>-9</b>	-13	-13
Total Dissolved Solids			<b>285.5</b>	275.0	334.0
Carboxylate			<b>fail</b>	fail	fail

### CORROSION INHIBITORS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D6130	0	<b>11</b>	73	31
Phosphorus	ppm	ASTM D6130	0	<b>0</b>	36	5
Boron	ppm	ASTM D6130	0	<b>0</b>	29	10
Molybdenum	ppm	ASTM D6130	950	<b>408</b>	985	913

### CORROSION

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D6130	>15	<b>5</b>	2	1
Aluminum	ppm	ASTM D6130	>10	<b>0</b>	<1	<1
Copper	ppm	ASTM D6130	>10	<b>&lt;1</b>	2	2
Lead	ppm	ASTM D6130	>10	<b>&lt;1</b>	1	<1
Tin	ppm	ASTM D6130	>10	<b>0</b>	1	0
Zinc	ppm	ASTM D6130		<b>0</b>	1	<1

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Chlorine	ppm	ASTM D6130		<b>11</b>	57	16

### CARRIER SALTS


	method	limit/base	current	history1	history2	
Sodium	ppm	ASTM D6130		<b>3013</b>	5550	5327
Potassium	ppm	ASTM D6130		<b>11</b>	219	157

### SCALE POTENTIAL

	method	limit/base	current	history1	history2	
Calcium	ppm	ASTM D6130		<b>3</b>	7	6
Magnesium	ppm	ASTM D6130		<b>4</b>	8	6









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	Red	Red
Coolant Appearance	*Visual	Clear	▲ sediment	normal	normal
Color					
Bottom					

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0805212

Lab Number : 06122872

Unique Number : 10937023

Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP, KF )

Received : 19 Mar 2024

Tested : 22 Mar 2024

Diagnosed : 22 Mar 2024 - Jonathan Hester

MARATHON PETROLEUM CO.

101 12TH ST

CATLETTSBURG, KY

US 41169

Contact: CORY GUMBERT

cagumbert@marathonpetroleum.com

T: (606)585-3950

F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)