




OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION



Area
PLOGER
 Machine Id
8185 - PLOGER
 Component
Transmission (Manual)
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

We recommend that you drain the fluid and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the fluid.

Fluid Condition

The AN level is above the recommended limit.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0900874	---	---
Sample Date	Client Info		16 Jan 2024	---	---
Machine Age	mls Client Info		617094	---	---
Oil Age	mls Client Info		0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			ABNORMAL	---	---

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m	>200	123	---	---
Chromium	ppm ASTM D5185m	>5	1	---	---
Nickel	ppm ASTM D5185m	>5	<1	---	---
Titanium	ppm ASTM D5185m		<1	---	---
Silver	ppm ASTM D5185m	>7	0	---	---
Aluminum	ppm ASTM D5185m	>25	19	---	---
Lead	ppm ASTM D5185m	>45	0	---	---
Copper	ppm ASTM D5185m	>225	59	---	---
Tin	ppm ASTM D5185m	>10	<1	---	---
Vanadium	ppm ASTM D5185m		0	---	---
Cadmium	ppm ASTM D5185m		0	---	---






ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m		259	---	---
Barium	ppm ASTM D5185m		0	---	---
Molybdenum	ppm ASTM D5185m		2	---	---
Manganese	ppm ASTM D5185m		20	---	---
Magnesium	ppm ASTM D5185m		0	---	---
Calcium	ppm ASTM D5185m		178	---	---
Phosphorus	ppm ASTM D5185m		1348	---	---
Zinc	ppm ASTM D5185m		6	---	---
Sulfur	ppm ASTM D5185m		1127	---	---

CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m	>125	13	---	---
Sodium	ppm ASTM D5185m		<1	---	---
Potassium	ppm ASTM D5185m	>20	0	---	---
Water	% ASTM D6304	>0.1	0.073	---	---
ppm Water	ppm ASTM D6304	>1000	739	---	---

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 164248	---	---
Particles >6µm	ASTM D7647	>2500	▲ 76095	---	---
Particles >14µm	ASTM D7647	>320	▲ 522	---	---
Particles >21µm	ASTM D7647	>80	46	---	---
Particles >38µm	ASTM D7647	>20	1	---	---
Particles >71µm	ASTM D7647	>4	0	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 25/23/16	---	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045		▲ 5.14	---	---

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	55.6	---	---
Visc @ 100°C	cSt	ASTM D445	9.5	---	---
Viscosity Index (VI)	Scale	ASTM D2270	155	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0900874 **Received** : 19 Mar 2024
Lab Number : **06123123** **Tested** : 22 Mar 2024
Unique Number : 10937274 **Diagnosed** : 22 Mar 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)