




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
UNIT 2 STARTER (S/N N15111903)

Component
Hydraulic System

Fluid
MOBIL DTE 25 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USP0006131	USP245476	USP245477
Sample Date	Client Info	29 Feb 2024	02 Nov 2023	07 Aug 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	5	<1	0
Chromium	ppm	ASTM D5185m >20	<1	0	0
Nickel	ppm	ASTM D5185m >20	0	0	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	<1
Aluminum	ppm	ASTM D5185m >20	<1	0	0
Lead	ppm	ASTM D5185m >20	4	6	6
Copper	ppm	ASTM D5185m >20	6	6	6
Tin	ppm	ASTM D5185m >20	0	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	<1	0
Barium	ppm	ASTM D5185m	0	3	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	3	4	0
Calcium	ppm	ASTM D5185m	133	116	144
Phosphorus	ppm	ASTM D5185m	512	445	503
Zinc	ppm	ASTM D5185m	653	631	706
Sulfur	ppm	ASTM D5185m	6302	5148	5625

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	1	12	<1
Sodium	ppm	ASTM D5185m	4	10	<1
Potassium	ppm	ASTM D5185m >20	0	7	1
Water	%	ASTM D6304 >0.05	0.006	▲ 0.228	0.011
ppm Water	ppm	ASTM D6304 >500	70	▲ 2280	119.0

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 12800	---	393
Particles >6µm	ASTM D7647 >1300	▲ 3404	---	98
Particles >14µm	ASTM D7647 >160	▲ 238	---	13
Particles >21µm	ASTM D7647 >40	▲ 67	---	5
Particles >38µm	ASTM D7647 >10	3	---	0
Particles >71µm	ASTM D7647 >3	1	---	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 21/19/15	---	16/14/11


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.03	0.93	0.99




OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	NONE	▲ LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	● HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.2	43.3	43.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USP0006131
 Lab Number : 06123154
 Unique Number : 10937305
 Test Package : IND 2

NRG ENERGY CENTER - SMYRNA LLC - DCOSMY
 217 ARTISAN DR
 SMYRNA, DE
 US 19977
 Contact: JERRY WIEGAND

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (302)659-0200

F: (302)659-0600