




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
KAESER CSD-75 5587739 (S/N 1228)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA013760	KCPA004052	KCP47081
Sample Date	Client Info		11 Mar 2024	13 Jul 2023	09 Nov 2022
Machine Age	hrs	Client Info	47288	45400	43420
Oil Age	hrs	Client Info	1888	0	2179
Oil Changed	Client Info		Changed	N/A	Not Changd
Sample Status			ATTENTION	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	5	<1	2
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	0	<1	4
Titanium	ppm	ASTM D5185m >3	0	0	0
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >10	2	0	1
Lead	ppm	ASTM D5185m >10	0	0	1
Copper	ppm	ASTM D5185m >50	4	11	8
Tin	ppm	ASTM D5185m >10	0	<1	<1
Antimony	ppm	ASTM D5185m	---	---	---
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 90	0	0	8
Molybdenum	ppm	ASTM D5185m 0	3	0	<1
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 100	4	0	12
Calcium	ppm	ASTM D5185m 0	0	0	4
Phosphorus	ppm	ASTM D5185m 0	0	0	5
Zinc	ppm	ASTM D5185m 0	0	0	1
Sulfur	ppm	ASTM D5185m 23500	21516	22996	22500

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	0	<1	<1
Sodium	ppm	ASTM D5185m	2	2	3
Potassium	ppm	ASTM D5185m >20	0	2	3
Water	%	ASTM D6304 >0.05	0.004	0.006	0.019
ppm Water	ppm	ASTM D6304 >500	42	62.8	194.8






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		9320	6467	---
Particles >6µm	ASTM D7647 >1300		1741	2565	---
Particles >14µm	ASTM D7647 >80		96	427	---
Particles >21µm	ASTM D7647 >20		22	139	---
Particles >38µm	ASTM D7647 >4		1	4	---
Particles >71µm	ASTM D7647 >3		0	0	---
Oil Cleanliness	ISO 4406 (c) >--/17/13		20/18/14	20/19/16	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.51	0.56	0.48

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	48.7	50.4	47.9

SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				
Bottom				

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA013760 **Received** : 19 Mar 2024
Lab Number : 06123208 **Tested** : 20 Mar 2024
Unique Number : 10937359 **Diagnosed** : 21 Mar 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

ALTEC HILINE
 1255 PORT TERMINAL RD
 DULUTH, MN
 US 55802
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)